




Contents lists available at ScienceDirect

## Renewable Energy

journal homepage: [www.elsevier.com/locate/renene](http://www.elsevier.com/locate/renene)

# The cost of grid stability with 100 % clean, renewable energy for all purposes when countries are isolated versus interconnected

Mark Z. Jacobson <sup>a, \*</sup><sup>a</sup> Department of Civil and Environmental Engineering, Stanford University, Stanford, CA, 94305-4020, USA

## ARTICLE INFO

## Article history:

Received 14 May 2021

Received in revised form

1 July 2021

Accepted 25 July 2021

Available online 27 July 2021

## Keywords:

Renewable energy

Grid stability

Transmission

Intermittency

Blackouts

Storage

## ABSTRACT

This study examines the impacts on energy costs and requirements of interconnecting versus isolating the electric grids of countries in Western Europe when each country's all-purpose energy is provided by 100 % wind, water, and sunlight (WWS). A weather model is used to predict wind and solar fields and building heat and cold loads. A grid model is used to match electricity, heat, cold, and hydrogen demand with WWS supply; electricity, heat, cold, and hydrogen storage; and demand response. Stable solutions are found for all countries, including the smallest (Luxembourg and Gibraltar) and largest (France, Germany, Spain, Italy, and the United Kingdom), and for all combinations of countries. Results indicate that interconnecting countries reduces aggregate annual energy costs, overbuilding of generators and storage, energy shedding, and land/water area requirements in most, but not all, situations. Interconnecting Western Europe may decrease aggregate annual energy costs ~13 % relative to isolating each country. The best reductions are found by interconnecting hydropower-rich Norway with Denmark (20.6 %) and Northwestern Europe (13.7 %). Interconnecting the smallest countries, Luxembourg and Gibraltar, with larger countries benefits all countries. Whether isolated or interconnected, all countries examined, including France and Germany, can maintain a stable grid at low cost with 100 % WWS.

© 2021 Elsevier Ltd. All rights reserved.

## Broader context

With the increasing penetration of renewables in many countries, energy planners would like to ensure that electric power grids remains stable. Even when dominated by fossil fuels, an isolated grid may fail during an extreme weather event. Such an outage could happen in any isolated grid. This paper explores grid stability in the presence of 100 % clean, renewable energy for all purposes when individual countries are isolated versus interconnected on the grid. Fourteen countries in Western Europe are examined in a case study. Stable solutions are found for all individual countries in isolation and all combinations of countries under all weather conditions. Results indicate that interconnecting the whole of Western Europe may decrease aggregate annual energy costs by ~13% relative to isolating each country's grid. The best benefits are found by interconnecting hydropower-rich Norway with Denmark and with all of Northwestern Europe. Interconnecting the smallest countries, Luxembourg and Gibraltar, with larger countries benefits

both the small and large countries but the smaller countries the most. Overall, interconnecting geographically diverse resources across country boundaries reduces aggregate annual energy costs, overbuilding of generators and storage, energy shedding, and land/water area requirements in most, but not all, situations. It also hedges against a sudden loss of renewable supply in one region but not others during an extreme weather event.

## Introduction

With the increasing penetration of clean, renewable energy in many countries, an important issue is how to keep the grid stable continuously. One potential method is to interconnect geographically-dispersed renewable energy resources across country boundaries. This study examines whether such interconnections are, indeed, helpful for maintaining grid stability at low cost.

At least 61 countries worldwide have committed to providing 100 % of their electricity from renewable sources [1]. Commitments by cities, states, and businesses to provide 100 % of their electricity or all energy from renewables number in the hundreds [2]. To ensure that 100 % renewable energy policies will allow the

\* Corresponding author:

E-mail address: [jacobson@stanford.edu](mailto:jacobson@stanford.edu).

electricity grid to remain stable, many studies have examined the feasibility of matching electricity and/or heat demand with supply, storage, and/or demand response upon transitioning one or more energy sectors to 100 % renewables [3–26].

However, less work has been done on the benefits of interconnecting versus isolating the electric power grids among multiple countries upon a transition to 100 % renewable electricity. Some studies on the subject are as follows. Archer and Jacobson [27] concluded from wind data alone, “When multiple wind sites are considered, the number of days with no wind power and the standard deviation of the wind speed, integrated across all sites, are substantially reduced in comparison with when one wind site is considered. Therefore a network of wind farms in locations with high annual mean wind speeds may provide a reliable and abundant source of electric power.” That study thus suggested that interconnecting a geographically dispersed 100 % intermittent electricity system would reduce intermittency among all interconnected generators. Archer and Jacobson [28] subsequently found that interconnecting geographically-dispersed wind farms not only smoothed out power supply among all farms but also reduced transmission requirements. Czisch [3] simulated the benefits of interconnecting the wind and solar resources of Europe with those of western Eurasia, the Middle East, and North Africa through high-voltage direct-current (HVDC) transmission lines. Blakers et al. [29] explored the benefits of transmitting Australia's solar energy to Southeast Asia through HVDC lines. Grossman et al. [30] simulated the benefit of interconnecting solar production across multiple time zones to reduce solar output variability aggregated among all time zones. Bogdanov and Breyer [16] found that interconnecting 13 regions in Northeast Asia resulted in lower energy costs than an isolated system. Aghahosseini et al. [24] found that interconnecting North and South America reduced overall system energy costs slightly relative to if each continent were isolated from the other. Martin et al. [31] used an optimization model to conclude that by trading electricity and sharing emission targets, U.S. states can reduce both electricity costs and carbon emissions.

The present study builds upon these previous ones to examine the benefits of interconnecting versus isolating individual countries in western Europe that have vastly different renewable energy resources from each other. This study uses a unique combination of tools (spreadsheet model, weather prediction model, and grid integration model) not used in previously analyses to quantify the benefits of interconnecting. This study differs from our own previous grid integration studies [14,22,25] in that it compares the cost and other parameters of keeping the grid stable when countries are completely isolated versus fully interconnected with each other. This was not done in our previous studies. This study is also unique compared with previous studies that have examined interconnection versus isolation as it uses consistent future fields of wind and solar generation and building heat and cold loads every 30 s for a year. It also uses a trial-and-error grid simulation model rather than an optimization model (the Methods section discusses the differences), it examines unique combinations of countries, and it examines several parameters not considered in previous studies.

Interconnecting grids across multiple countries or states may be important from a grid security point of view, as seen by the inability of the Texas grid to import electricity during a February 14–18, 2021, severe storm and ensuing blackout. The Texas grid failed largely because low temperatures caused natural gas, coal, nuclear, and wind electricity generators to fail, with natural gas being the largest source of failure. A portion of frozen wind turbines were shut because none had de-icing equipment. The present study does not examine a case of widespread equipment failure, only the impact of intermittency, including during extreme weather events, on grid failure.

This study also examines whether it is possible to supply all energy needs for all purposes continuously to even small countries, such as Luxembourg and Gibraltar, with internally-produced 100 % clean, renewable energy and how interconnecting those countries with their neighbors may reduce energy costs. The study further examines how France, which provides 70 % of its electricity from nuclear, might power not only its electricity sector, but all energy sectors, with 100 % internally-produced wind, water, and solar (WWS) and how the resulting cost of energy changes upon interconnecting France with its neighbors. The study additionally examines how countries with substantial hydropower resources, such as Norway and Switzerland, improve the ability of their neighbors, through grid interconnection, to balance renewable supply with demand, storage, and demand response.

In reality, all countries in Europe are interconnected to some degree with each other, so the two extreme cases examined here, zero interconnection and perfect interconnection do not represent the reality of the current interconnection situation in Europe. However, they do bound the current situation, so a showing that grids can stay stable at low cost with 100 % WWS and storage in both the isolated and fully-interconnected cases suggests they can stay stable at low cost in cases in-between.

## Methods

The strategy behind this study is to simulate matching time-dependent 2050 demand with time-dependent WWS electricity and heat supply; electrolytic hydrogen production; electricity, heat, cold, and hydrogen storage; and demand response for individual countries and for combinations of countries in Western Europe (Table 1). This is done through the use of three tools: a spreadsheet model, a weather prediction model, and a grid integration model. The use of each tool is discussed, in turn.

The first tool used is a spreadsheet model. In this model, annual average (but not continuous) 2050 WWS electricity and heat loads for each individual country considered are derived, as in Jacobson et al. [25]. Such projections start with IEA [32] 2016 business-as-usual (BAU) end-use energy consumption data for all energy sectors (residential, commercial, transport, industrial, agriculture/forestry/fishing, and military), and for each energy type (oil, natural gas, coal, electricity, waste heat, solar and geothermal heat, and biofuels and waste) within each sector. Country data are summed here by region to provide the results in Table S1, which gives 2016 BAU loads by sector for each region and individual country considered here.

2016 BAU data are then projected for each country, sector, and fuel type to 2040 using “BAU reference scenario” projections for the same sectors and fuel types for one of 16 world regions from EIA [33]. The reference scenario is one of moderate economic growth and accounts for policies in different countries, population growth, economic and energy growth, some renewable energy growth, modest energy efficiency measures, and reduced energy use. Consumption of each fuel type in each sector in each country is then extrapolated from 2040 to 2050 using a 10-year moving linear extrapolation. Results are then summed here over all countries in each region. Table S1 and Table 2 give the resulting 2050 annual average BAU loads for each country and region.

The 2050 BAU energy for each fuel type in each sector and country is then transitioned to 2050 WWS electricity and heat in the same way as in Ref. 25. WWS electricity generators include onshore and offshore wind turbines, rooftop and utility-scale solar photovoltaics (PV), concentrated solar power (CSP) plants, tidal and wave devices, geothermal electric power plants, and existing hydroelectric power plants (no new reservoirs are assumed). WWS heat generators include solar and geothermal heat.

**Table 1**  
The regions and country(ies) within each region simulated.

Country or region	Name(s) of country(ies) within country or region
Belgium	Belgium
Denmark	Denmark
France	France
Germany	Germany
Gibraltar	Gibraltar
Italy	Italy
Luxembourg	Luxembourg
Netherlands	Netherlands
Norway	Norway
Portugal	Portugal
Spain	Spain
Sweden	Sweden
Switzerland	Switzerland
United Kingdom	United Kingdom
Nor-Den	Denmark, Norway
Nor-Den-Swe-Ger	Denmark, Germany, Norway, Sweden
Northern Europe	Belgium, Denmark, Germany, Luxembourg, Netherlands, Norway, Sweden
Swi-Fra	France, Switzerland
Swi-Ger	Germany, Switzerland
Northwest Europe	Belgium, Denmark, France, Germany, Luxembourg, Netherlands, Norway, Sweden, Switzerland
Swi-Ita	Italy, Switzerland
Spa-Por-Gib	Gibraltar, Portugal, Spain
Western Europe	Belgium, Denmark, France, Germany, Gibraltar, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland
All Europe	Albania, Austria, Belarus, Belgium, Bosnia-Herzegovina, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Gibraltar, Greece, Hungary, Ireland, Italy, Kosovo, Latvia, Lithuania, Luxembourg, Macedonia, Malta, Moldova Republic, Montenegro, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Ukraine, United Kingdom

Thus, for example, the source of building heat is moved from fossil fuels or bioenergy to air- and ground-source heat pumps running on WWS electricity and direct solar thermal or geothermal heat. Building cooling is provided by electric heat pumps.

Fossil fuel and biofuel vehicles are transitioned primarily to battery electric (BE) vehicles and some hydrogen fuel cell (HFC) vehicles, where the hydrogen in that case is produced using WWS electricity (i.e., green hydrogen). BE vehicles are assumed to dominate short- and long-distance light-duty ground transportation, construction machines, agricultural equipment, short- and moderate-distance trains (except where powered by electric rails or overhead wires), ferries, speedboats, short-distance ships, and short-haul aircraft traveling under 1500 km. HFC vehicles are assumed to make up all long-distance, heavy payload transport by road, rail, water, and air.

High-temperature industrial processes are electrified with electric arc furnaces, induction furnaces, resistance furnaces, dielectric heaters, and electron beam heaters.

Table S1 and Table 2 summarize the resulting 2050 WWS loads in each country and region examined here. As a result of electrification of all energy sectors, all-purpose end-use power demand decreases in each country or region by between 47.9 % and 75.8 % (Table S1). The world average (among 143 countries) reduction is 57.1 %, of which 38.3% points are due to the efficiency of using WWS electricity over combustion; 12.1% points are due to eliminating energy in the mining, transporting, and refining of fossil fuels; and 6.6% points are due to end-use energy efficiency improvements and reduced energy use beyond those in the BAU case [25]. Of the 38.3 % reduction due to the efficiency advantage of WWS electricity, 21.7% points are due to the efficiency advantage of WWS transportation, 3.4% points are due to the efficiency advantage of WWS electricity for industrial heat, and 13.2% points are due to the efficiency advantage of electric heat pumps.

Whereas, electrification of all energy sectors reduces overall energy needs substantially, it increases electricity requirements. For example, electricity provides ~21.5 % of all 2050 BAU end-use energy among all 143 countries in Ref. 25. Following almost-complete electrification of non-electricity sectors and providing all electricity with WWS in 2050, electricity and some direct heat provide 100 % of all end-use energy, but only 86 % more electricity than in the BAU case. As calculated here, in Europe, a mean of 51 % more electricity is required with WWS than with BAU (Table S3), but even with this increase, total end-use energy is still 59 % lower with WWS than with BAU (Table S1). In sum, overall energy requirements decrease but electricity requirements increase with WWS.

Next, a mix of WWS resources is estimated for each country to meet its all-sector annual-average end-use energy demand, as in Ref. 25. The mix is determined after a WWS resource analysis is performed for each country. Air pollution and climate damage in 2050 are estimated for each country, and the social cost benefits of reducing such damage with WWS are then calculated.

Here, we start with the annual-average 2050 WWS electricity and heat loads for each country of interest and the estimated number of WWS generators needed to meet such loads in the annual average, from Ref. 25. We then separate the total electricity and heat loads into flexible and inflexible loads, in the same manner as in Ref. 34, but for the countries and regions considered here. Flexible loads are loads subject to heat or cold storage (district heat storage or building water tank storage) and loads subject to demand response. Loads subject to demand response can be shifted forward in time a maximum of 8 h. Loads subject to heat/cold storage can be met with such storage or current or stored electricity. Inflexible loads must be met immediately with either current or stored electricity.

Next we run new one-year global simulations with the GATOR-GCMOM (Gas, Aerosol, Transport, Radiation, General Circulation,

**Table 2**  
Key results from this study.

Country or region	<sup>a</sup> Annual average BAU end-use load (GW)	<sup>b</sup> Annual average WWS end-use load (GW)	<sup>c</sup> Mean WWS Total capital cost (\$tril 2013)	<sup>d</sup> Mean BAU (¢/kWh-all energy)	<sup>e</sup> Mean WWS (¢/kWh-all energy)	<sup>f</sup> Mean annual WWS all-energy private and social cost (\$bil/yr)	<sup>g</sup> Mean annual BAU all-energy private cost (\$bil/yr)	<sup>h</sup> Mean annual BAU health cost (\$bil/yr)	<sup>i</sup> Mean annual BAU climate cost (\$bil/yr)	<sup>j</sup> = g + h + i Mean annual BAU total social cost (\$bil/yr)
Belgium	69.7	29.2	0.302	11.12	10.5	26.9	67.9	23.4	68.9	160
Denmark	25.9	9.6	0.106	12.61	13.0	11.0	28.6	10.5	22.2	61.2
France	251.6	112.4	0.979	9.39	9.26	91.1	206.9	102.9	223.7	533.6
Germany	366.4	155.2	1.785	10.85	11.3	154.1	348.3	199.7	526.8	1075
Gibraltar	5.4	1.3	0.017	10.84	14.8	1.7	5.16	0.22	0.41	5.79
Italy	217.4	83.2	0.570	11.06	8.42	61.4	210.6	168.9	238.8	618.2
Luxembourg	6.0	2.3	0.039	11.96	15.9	3.2	6.33	1.42	6.31	14.06
Netherlands	105.7	40.1	0.422	11.15	11.2	39.2	103.2	35.8	115.6	254.6
Norway	47.0	20.2	0.033	6.61	6.10	10.8	27.2	6.9	31.0	65.1
Portugal	30.3	13.1	0.102	10.89	9.54	10.9	28.9	14.0	37.6	80.4
Spain	165.3	65.7	0.412	10.84	8.21	47.2	157.0	79.5	186.3	422.8
Sweden	58.5	30.5	0.163	8.70	8.33	22.2	44.6	10.4	33.7	88.6
Switzerland	33.6	16.0	0.040	7.79	6.15	8.6	22.9	12.4	26.3	61.6
United Kingdom	233.7	88.8	0.880	11.16	10.3	80.1	228	137	251	616
Nor-Den	72.8	29.8	0.084	8.74	6.63	17.3	55.8	17.3	53.2	126.3
Nor-Den-Swe-Ger	497.8	215.5	1.890	10.29	9.77	184.4	449	227	614	1290
Northern Europe	679.2	287.1	2.509	10.52	9.70	243.9	626	288	804	1718
Swi-Fra	285.2	128.4	0.981	9.20	8.66	97.4	230	115	250	595
Swi-Ger	400.1	171.2	1.797	10.59	10.6	159.6	371	212	553	1136
Northwest Europe	964.4	415.5	3.036	10.13	8.71	316.9	856	403	1054	2314
Swi-Ita	251.0	99.2	0.655	10.62	8.23	71.5	234	181	265	680
Spa-Por-Gib	201.0	80.1	0.508	10.85	8.17	57.3	191	94	224	509
Western Europe	1383	578.7	4.043	10.38	8.39	425.6	1257	666	1517	3441
All Europe	2293	939.7	6.407	10.34	8.30	683.7	2076	1589	2723	6388

Aggregate private energy cost (Columns f or g) equals annual average end use load (Column b or a) multiplied by the mean cost per unit energy (Column e or d, respectively) and by 8760 h per year. Tables S10–S13 give parameters for determining the costs of storage, energy generation, health damage, and climate damage, respectively. Table S10 gives the lifecycle costs and efficiencies of storage for each storage type. The discount rate used for generation, storage, transmission/distribution, and social costs is a social discount rate of 2 (1–3)% [25].

- <sup>a</sup> 2050 annual-average end-use BAU load.
- <sup>b</sup> 2050 annual-average end-use WWS load.
- <sup>c</sup> Present value of the mean total capital cost for new WWS electricity, heat, cold, and hydrogen generation and storage and long-distance transmission.
- <sup>d</sup> Mean levelized private costs of all BAU energy (¢/kWh-all-energy-sectors, averaged between today and 2050, in USD 2013). 0.83 Euro = 1 USD on May 13, 2021.
- <sup>e</sup> Same as (d), but for WWS energy.
- <sup>f</sup> WWS private (equals social) energy cost (2013 USD \$billion/yr).
- <sup>g</sup> BAU private energy cost (2013 USD \$billion/yr).
- <sup>h</sup> BAU health cost (2013 USD \$billion/yr).
- <sup>i</sup> BAU climate cost (2013 USD \$billion/yr).
- <sup>j</sup> BAU total social cost (2013 USD \$billion/yr).

Mesoscale, and Ocean Model) [35–38] weather-climate-air-pollution model. This is the second tool used. The model predicts time-dependent (every 30 s) building heating and cooling loads (which were not previously calculated in Ref. 25), onshore and offshore wind electricity; rooftop and utility PV electricity; CSP electricity; and solar thermal heat supply for each country assuming the baseline number of generators estimated to meet annual average loads. From the offshore wind estimates, time-dependent wave power estimates are also derived [25].

GATOR-GCMOM accounts for the reduction in the wind's kinetic energy and speed due to the competition among wind turbines for limited available kinetic energy [37], the temperature-dependence of PV output [38], and the reduction in sunlight to building and the ground due to the conversion of radiation to electricity by solar devices [22,25]. It also accounts for (1) changes in air and ground temperature due to power extraction by solar and wind devices and subsequent electricity use [22,25]; (2) impacts of time-dependent gas, aerosol, and cloud concentrations on solar radiation and wind fields [36]; (3) solar radiation to rooftop PV panels at a fixed optimal tilt [38]; and (4) solar radiation to utility PV panels, half of

which are at an optimal tilt and the other half of which track the sun with single-axis horizontal tracking [38].

Thermal loads in GATOR-GCMOM are calculated as follows [34]. The model predicts the ambient air temperature in each surface grid cell in each country and compares it with an ideal building interior temperature, 294.261 K (70 °F). It then calculates how much heating or cooling energy is needed every 30 s to maintain the interior temperature among all buildings in the grid cell (assuming an average U-value and surface area for buildings and a given number of buildings in each grid cell). The time series among all grid cells in a country are summed. The time-dependent result is then scaled by the ratio of the annual average 2050 heating or cooling demands required in a 100 % WWS world from Ref. 25 to the annual average heating or cooling load from the time series to obtain time-dependent heating and cooling loads that, when averaged, exactly equal the annual average load.

Time-dependent 2050 inflexible loads for each country are obtained by scaling hourly 2016 electricity loads for all but one European country from ENTSO-E [39] by the ratio of the annual average 2050 WWS inflexible load to the annual average load from

the data profile. For Gibraltar, 2030 hourly load data from Neocarbon Energy [40] are used.

The third tool used here is the grid integration model, LOADMATCH [14,22,25]. This model simulates matching the time-dependent electricity and heat loads and losses with supply, storage, and demand response. Time-dependent (30-s resolution) 2050 WWS supplies and thermal loads from GATOR-GCMOM are inputs into LOADMATCH.

LOADMATCH is a trial-and-error grid simulation model. It works by running multiple simulations, one at a time. Each simulation marches forward one or more years, one timestep at a time, just as the real world does. The main constraint during a simulation is that the summed electricity, heat, cold, and hydrogen load, adjusted by demand response, must match energy supply and storage every timestep for an entire simulation period. If load is not met during any 30-s timestep, the simulation stops. Inputs (either the nameplate capacity of one or more generators; the peak charge rate, peak discharge rate, or peak capacity of storage; or characteristics of demand response) are then adjusted one at a time based on an examination of what caused the load mismatch (hence the description “trial-and-error” model). For example, if hydrogen or underground thermal energy storage is full when a mismatch occurs, a solution is to increase slightly the storage capacity of the one that is full. In cases where the cause is uncertain, generator nameplate capacities and storage peak discharge rates are increased one generator and one storage device at a time. Each update, another simulation is run from the beginning. New simulations are run until load is met every time step of the simulation period. After load is met once, additional simulations are performed with further-adjusted inputs to generate a set of lower-cost solutions that match load every timestep. The lowest cost solution among all successful simulations is then selected. The ratio of the final to initial nameplate capacity for each generator is the capacity adjustment factor (Table S5).

Unlike with an optimization model, which solves among all timesteps simultaneously, a trial-and-error model does not know the weather during the next timestep. Because a trial-and-error model is non-iterative, it requires less than a minute for a 3-year simulation with a 30-s timestep [25]. This is 1/500th to 1/100,000<sup>th</sup> the computer time of an optimization model for the same number of timesteps. The disadvantage of a trial-and-error model compared with an optimization model is that the former does not determine the least cost solution out of all possible solutions. Instead, it produces a set of viable solutions, from which the lowest-cost solution is selected.

Table S4 summarizes many of the processes treated in LOADMATCH. Model inputs are as follows: (1) time-dependent electricity produced from onshore and offshore wind turbines, wave devices, tidal turbines, rooftop PV panels, utility PV plants, CSP plants, and geothermal plants; (2) a hydropower plant peak discharge rate (nameplate capacity), which is set to the present-day nameplate capacity for this study, a hydropower plant mean recharge rate (from rainfall), and a hydropower plant annual average electricity output; (3) time-dependent geothermal heat and solar-thermal heat generation rates; (4) specifications of hot-water and chilled-water sensible-heat thermal energy storage (HW-STES and CW-STES) (peak charge rate, peak discharge rate, peak storage capacity, losses into storage, and losses out of storage); (5) specifications of underground thermal energy storage (UTES), including borehole, water pit, and aquifer storage; (6) specifications of ice storage (ICE); (7) specifications of electricity storage in pumped hydropower storage (PHS), phase-change materials coupled with CSP (CSP-PCM), and batteries; (8) specifications of hydrogen (for use in transportation) electrolysis, compression, and storage equipment; (9) specifications of electric heat pumps for air and water heating

and cooling; (10) specifications of a demand response system; (11) specifications of losses along short- and long-distance transmission and distribution lines; (12) time-dependent electricity, heat, cold, and hydrogen loads, (13) scheduled and unscheduled maintenance downtimes for generators, storage, and transmission, and (14) costs of generation, storage, transmission and distribution, health damage, and climate damage.

Table S11 provides cost parameters of energy-generating technologies, short- and long-distance transmission, and distribution as well as lifetimes of energy-generating technologies. Table S10 provides cost parameters and lifetimes of storage technologies. Table S12 provides parameters for determining health costs. Table S13 provides social cost of carbon estimates.

One assumption here is that transmission is perfectly interconnected within each country and among all combinations of countries. This is because the countries considered here are small enough that they already have or could have well-interconnected transmission and distribution systems. Simulations of two or more interconnected countries are performed by aggregating their loads as if they were one country, so it is not possible to determine what the precise transfers of load are between countries. However, the study does estimate transmission and distribution (T&D) costs and T&D energy losses (Table S11 and Table S14) resulting from all transfers of electricity. Short-distance transmission costs, long-distance high-voltage direct current (HVDC) transmission costs, and distribution costs are tracked using a cost per kWh of electricity transmitted. HVDC capital costs are also tracked (Table S14). All electricity consumed is assumed to incur a short-distance transmission and distribution costs. When individual countries are considered, only 15 % of all electricity consumed is assumed to be subject to HVDC transmission cost in Germany, the United Kingdom, France, Norway, Sweden, Spain, Portugal, and Italy; 10 % is subject to HVDC cost in Denmark, the Netherlands, Belgium, and Switzerland; and 0 % is subject to HVDC cost in Luxembourg and Gibraltar (see Table S11, footnotes). When any two or more countries is interconnected, 30 % of all electricity consumed is subject to HVDC cost.

While the paper sacrifices spatial resolution needed to treat transmission explicitly, it treats time resolution (30 s) two orders of magnitude higher than in other studies (3600 s). This study also accounts for the spatial variation of wind and solar resources and thermal loads within countries, since all such calculations are performed with the global, 3-D gridded GATOR-GCMOM model.

Next, the order of operations in LOADMATCH, including how the model treats excess generation over demand and excess demand over generation, is summarized [25]. The first situation discussed is one in which the current (instantaneous) supply of WWS electricity or heat exceeds the current electricity or heat demand (load). The total load, whether for electricity or heat, consists of flexible and inflexible loads. Whereas flexible loads may be shifted forward in time with demand response, inflexible loads must be met immediately. If WWS instantaneous electricity or heat supply exceeds the instantaneous inflexible electricity or heat load, then the supply is used to satisfy that load. The excess WWS is then used to satisfy as much current flexible electric or heat load as possible. If any excess electricity exists after inflexible and current flexible loads are met, the excess electricity is sent to fill electricity, heat, cold, or hydrogen storage.

Electricity storage is filled first. Excess high-temperature heat from CSP goes to thermal energy storage in a phase-change material. If CSP storage is full, remaining high-temperature heat produces electricity that is used, along with excess electricity from other sources, to charge pumped hydropower storage followed by battery storage, cold water storage, ice storage, hot water tank storage, and underground thermal energy storage. Remaining

excess electricity is used to produce hydrogen. Any residual after that is shed.

Heat and cold storage are filled by using the excess electricity to run an air source or ground source heat pump to move heat or cold from the air, water, or ground to the thermal storage medium. Hydrogen storage is filled by using electricity in an electrolyzer to produce hydrogen and in a compressor to compress the hydrogen, which is then moved to a storage tank.

If any excess direct geothermal or solar heat exists after it is used to satisfy inflexible and flexible heat loads, the remainder is used to fill either district heat storage (water tank and underground heat storage) or home's hot water tank heat storage.

The second situation discussed is one in which current load exceeds WWS electricity or heat supply. When current inflexible plus flexible electricity load exceeds the current WWS electricity supply from the grid, the first step is to use electricity storage (CSP, pumped hydro, hydropower, and battery storage, in that order) to fill in the gap in supply. Sensitivity tests found that the order of charging and discharging electricity storage made little difference in the results. Also a question arises as to whether these options can be used to store electricity seasonally, such as for up to six months? Hydropower reservoirs can be used strategically for long term electricity storage. Although the storage time of batteries is only 1.94 h (Table S8), batteries can be concatenated together in series to provide multi-day or multi-week storage, but at the peak discharge rate of one battery. Alternatively, they can be used all at once in parallel to provide storage for 1.94 h but at the peak discharge rate of the sum of all batteries. As such, batteries, like hydropower, are versatile for providing long-term or short-term storage. However, batteries are currently somewhat expensive. Because of the availability of both hydropower and batteries, stable solutions are found here for all countries and regions without other seasonal electricity storage.

Electricity from storage is used to supply inflexible load first, followed by flexible load. If electricity storage becomes depleted and flexible load persists, demand response is used to shift the flexible load to a future hour.

If the inflexible plus flexible heat load subject to storage exceeds WWS direct heat supply, then stored district heat (in water tanks and underground storage) is used to satisfy district heat loads subject to storage, and heat stored in domestic hot water tanks is used to satisfy building water heat loads. If stored heat becomes exhausted, then any remaining low-temperature air or water heat load becomes either an inflexible load (85 %), which must be met immediately with electricity, or a flexible load (15 %), which can either be met with current or stored electricity or shifted forward in time with demand response, then turned into an inflexible load.

Similarly, if the inflexible plus flexible cold load subject to storage exceeds cold storage (in ice or water), excess cold load becomes either an inflexible load (85 %), which must be met immediately with current or stored electricity, or a flexible load (15 %), which can be met with current or stored electricity or shifted forward in time with demand response, then turned into an inflexible load.

Finally, if current hydrogen load depletes hydrogen storage, the remaining hydrogen load becomes an inflexible electrical load that must be met immediately with current or stored electricity.

In any of the cases above, if electricity is not available to meet the remaining inflexible load, the simulation stops and must be restarted after nameplate capacities of generation and/or storage are increased.

Because the model does not permit load loss at any time, it is designed to exceed the utility industry standard of load loss once every 10 years.

## Results and discussion

GATOR-GCMOM was run on the global scale for one year (2050) at  $1.5^\circ \times 1.5^\circ$  horizontal resolution. The model produced electricity from onshore and offshore wind turbines, rooftop and utility PV, and CSP; heat from solar thermal collectors; building air heating loads; and building air cooling loads every 30 s for each country in Table 1. Those results, along with the demand profiles previously described, were fed into LOADMATCH, which was run for each individual country and group of countries – 24 simulations total (Table 1) for a year.

LOADMATCH was run for each country and region with initial generator nameplate capacities and storage characteristics by country, from Ref. 25, that were estimated to meet annual average WWS loads. For each region, values were summed over all countries in the region. If the first simulation for a country or region did not result in a stable solution, inputs were adjusted each subsequent simulation until a zero-load-loss solution was found among all 30-s timesteps during 2050. Success typically occurred within 10 simulation attempts. After one successful simulation, the model was run for another 4 to 20 simulations, with further adjustments, to find additional lower-cost solutions. Thus, multiple zero-load loss solutions were obtained for each country and region, but only the lowest-cost solution is presented here. Table 3 provides the final generator nameplate capacities, whereas Table S5 provides capacity adjustment factors, which are the ratios of the final to first-guess generator nameplate capacities. Table S6 provides the final simulation-averaged capacity factors in each country or region. Table S7 provides the final storage peak charge rates, discharge rates, and capacities (assuming the maximum storage times at peak discharge given in Table S8).

Figure S1 shows the full 2050 time series of WWS power generation versus load plus losses plus changes in storage plus shedding for most countries and regions. Supply matched total load (end-use load plus changes in storage plus losses plus shedding) every 30 s for the year in all 24 countries and groups of countries. Table S9 confirms exact energy conservation numerically. It provides a detailed budget of energy demand, supply, losses, and changes in storage for each country and region. For example, it shows that, for “All Europe,” demand plus losses equals 10,216 TWh during the simulation, and this exactly equals supply plus changes of storage. Of that total, 8220.824 TWh is given in Table S9 as the end-use demand. Dividing that by 8747.4875 h of simulation gives 0.940 TW of annual-average end-use WWS load, which is the total shown in Table 2 for “All Europe.”

Tables 2, S14, and S15 summarize the resulting energy private and social costs and the sources of cost data (in the footnotes) for each of the 24 sets of simulations. Energy social costs are energy private costs plus health and climate costs due to energy. The WWS private cost includes the costs of new electricity and heat generation, short-distance transmission, long-distance transmission, distribution, heat storage, cold storage, electricity storage, and hydrogen production/compression/storage. WWS energy private costs (costs of energy alone) are assumed to equal WWS energy social costs, since in 2050, WWS generators, storage, and transmission will result in zero pollutant emissions while in use. Also, their manufacture and decommissioning will be free of energy-related emissions. The health and climate costs of zero emissions are zero.

Table S15 indicates that, for each of the 14 individual countries, WWS reduced annual aggregate private costs ( $R_{APC}$ ) by 49 %–71 % and social costs ( $R_{ASC}$ ) by 71 %–90 %. Thus, even without interconnecting countries, transitioning individual Western European countries reduces costs substantially relative to BAU. This result applies not only to the smallest countries, Gibraltar and

**Table 3**

Final (from LOADMATCH) 2050 total (existing plus new) nameplate capacity (GW) of WWS generators by region obtained here needed to match power demand with supply and storage continuously over time.

Country or region	On-shore wind	Off-shore wind	Resi-dential roof PV	Comm/govt roof PV	Utility PV	CSP with stor-age	Geo elec-tricity	Hydro	Wave	Tidal	Solar ther-mal heat	Geo heat	% of 2050 in 2018
Belgium	11.9	28.2	2.14	2.3	138.1	0	0	0.1	0	0.003	0.33	0.21	4.3
Denmark	27.3	11.7	3.07	2.0	9.6	0	0	0.009	0.8	0.073	0.89	0.35	14.4
France	162.5	33.6	72.7	86.9	171.2	0	0.04	18.5	4.1	1	1.63	2.35	8.6
Germany	238.5	94.7	73.6	275.4	344.8	0	0.03	4.5	1.1	0.035	14.0	2.85	12.1
Gibraltar	0.0	6.2	0.005	0	0	0	0	0	0	0.001	0	0	0.0
Italy	100	33.2	42.9	36.5	67.5	10.9	1.00	14.3	2.3	0.075	3.24	1.01	15.9
Luxembourg	2.0	0	0.31	0.4	11.4	0	0	0.034	0	0	0.03	0.00	2.4
Netherlands	21.1	60.9	3.07	5.1	145.9	0	0	0.037	0	0.012	0.61	0.79	4.3
Norway	5.7	2.1	3.08	0.7	3.3	0	0	30.4	0.2	0.35	0	1.30	70.8
Portugal	16.6	2.4	4.25	10.3	6.8	1.1	0.10	4.7	0.5	0.500	0.68	0.04	24.1
Spain	93.7	15.6	29.7	36.4	33.5	5.9	0.05	17.0	2.2	1.000	2.84	0.06	21.2
Sweden	32.8	12.5	6.31	3.7	29.0	0	0	16.4	0	0.100	0.34	5.60	28.2
Switzerland	6.5	0.0	2.96	6.3	6.7	0	0	13.9	0	0	1.15	1.73	48.7
United Kingdom	71.0	85.5	23.0	22.6	300.9	0	0	1.9	3.0	11.40	0.46	0.28	7.2
Nor-Den	18.0	7.8	6.01	2.4	11.2	0	0	30.5	1.0	0.423	0.89	1.65	52.0
Nor-Den-Swe-Ger	272.8	115.1	91.5	281.4	264.1	0	0.03	51.3	2.1	0.558	15.3	10.1	18.0
Northern Europe	340.2	182.7	99.2	292.3	478.5	0	0.03	51.5	2.1	0.573	16.2	11.1	14.7
Swi-Fra	206.6	35.4	78.6	99.4	82.1	4.5	0.04	32.4	4.1	1	2.78	4.08	12.1
Swi-Ger	258.1	75.7	79.5	302.6	278.7	0	0.03	18.3	1.1	0.035	15.2	4.58	14.1
Northwest Europe	462.7	225.2	177.8	207.7	631.5	4.5	0.07	83.9	6.2	1.573	19.0	15.2	15.4
Swi-Ita	114.3	33.2	47.7	46.6	83.6	7.8	1.00	28.2	2.3	0.075	4.38	2.75	18.5
Spa-Por-Gib	109.8	23.4	34.0	46.7	38.6	6.9	0.15	21.7	2.6	1.5	3.52	0.10	21.4
Western Europe	690.7	250.1	273.9	311.7	725.3	19.2	1.22	119.9	11.2	3.1	25.8	16.3	16.1
All Europe	1231	394.5	317.3	506.6	1106	21.1	3.17	167.4	15.5	15.0	36.7	22.3	12.4

The nameplate capacity equals the maximum possible instantaneous discharge rate. The last column is the percent of the total nameplate capacity needed in 2050 (the sum of all other columns in the table) that was already installed with WWS by the end of 2018.

Luxembourg, but also to France, Germany, Italy, Spain, and the UK, for example.

Fig. 1 compares the aggregate annual WWS cost when each of nine regions is interconnected versus when each country within each region provides 100 % of its own WWS energy in isolation

from the other countries in the region. Let's start with Denmark and Norway. The costs per unit energy for 100 % WWS in Denmark and Norway, when each grid is isolated from each other, are 13.0 and 6.1 ¢/kWh-all-energy (USD 2013), respectively (Table 1). The corresponding mean annual aggregate cost of energy (cost per unit




Fig. 1. 2050 annual private cost of WWS energy (USD 2013) for groups of countries in Table 1 found here when the countries are interconnected among themselves versus isolated and the resulting totals added. Values are from Table 1.

energy multiplied by energy consumed per year) in each case is \$11.0 and \$10.8 billion/yr, respectively (Table 1). The cost per unit energy to keep the grid stable in Norway is low due to the substantial built-in hydropower storage already available. In fact, In 2018, Norway already has 71 % of the WWS nameplate capacity it needs to supply 100 % WWS across all energy sectors in 2050 (Table 3). Denmark, on the other hand, has relatively little hydro (and only 14.4 % of its needed nameplate capacity already installed in 2018), so Denmark needs to spend on additional storage and on additional electricity generation beyond that needed for annual average power. As a result of the overbuilding, 29.4 % of all Denmark's energy is shed during the simulation in which its grid is isolated, whereas only 2.4 % of Norway's is shed (Table S9).

When the two countries are interconnected, Norwegian hydro is able to fill in the gaps in Denmark's WWS supply, reducing the need to overbuild generation or storage, thereby reducing shedding and annual aggregate costs substantially. For example, interconnecting Norway and Denmark eliminates the need for 200 GW of batteries in Denmark (Table S7) and reduces the overall nameplate capacity of generators summed between the two countries by 22.6 % (Fig. 2, Table 3). Shedding decreases 96 % relative to not interconnecting the countries (Fig. 3, Table S9). Aggregate annual WWS energy costs decline by 20.6 % (Fig. 1, Table 2).

Interconnecting Norway with other countries in addition to Denmark similarly reduces costs. Fig. 1 shows that combining Norway, Denmark, Sweden, and Germany reduces aggregate annual cost by ~7 % relative to isolating all those countries. Adding in the Netherlands, Belgium, and Luxembourg to that mix (Northern Europe), reduces overall energy cost by ~8.8 % relative to isolating the countries. Adding France and Switzerland to that group (Northwest Europe) reduces overall costs by ~13.7 %. Adding Italy, Spain, Portugal, and Gibraltar to that group (Western Europe) reduces overall costs by ~12.9 %. Lesser overall cost benefits are found by combining Switzerland with either Germany, France, or Italy. Part of the reason is that Switzerland has less than half the installed hydropower as Norway. Another reason is that WWS costs per unit energy in Germany, France, and Italy, when isolated, are all lower than in Denmark.

The most expensive countries per unit energy, when providing 100 % of their own WWS energy, are Luxembourg (15.9 ¢/kWh) and Gibraltar (14.8 ¢/kWh) (Table 2). When Luxembourg is interconnected with the seven countries of Northern Europe (Table 1), the average cost of WWS energy across all countries (including Luxembourg) is only 9.7 ¢/kWh (Table 2). In addition, the aggregate annual cost among all seven countries declines by 8.8 % (Fig. 1) and shedding declines by 29.7 % (Fig. 3). Similarly, when Gibraltar is interconnected with Spain and Portugal, the average cost of WWS energy across the three countries is 8.17 ¢/kWh, which is lower than that of either Spain, Portugal, or Gibraltar individually (Table 2). Finally, the aggregate annual cost among the three countries declines 4.3 % (Fig. 1) and shedding declines 8.6 % (Fig. 3) compared with when the countries are isolated. Thus, interconnecting benefits the smallest countries in a region the most but also usually benefits large countries.

When countries are interconnected, the country in the region that requires the most capital investment when it is isolated (Table S14) is likely to be the same country that must make the most investment when the countries are linked. For example, in the Norway-Denmark-Sweden-Germany region, Germany needs to make the most investment.

Table 2 indicates that the cost per unit energy in France, Spain, and Italy are all already relatively low (9.26, 8.21, and 8.42 ¢/kWh, respectively) when each countries provides 100 % of its own energy from WWS in isolation. This bodes well for France, for example, which then does not need to rely on nuclear power for electricity in the future. Because the WWS cost per unit energy is already low in France, Spain, and Italy, interconnecting these countries doesn't change costs substantially. For example, connecting Switzerland with Italy increases annual aggregate costs by ~2.1 % (Fig. 1) and connecting Switzerland with France decreases annual aggregate costs by only ~2.4 % (Fig. 1).

Footprint is the physical land, water surface, or sea floor surface area removed by an energy technology from use for any other purpose. Spacing is the area between some technologies, such as wind turbines, wave devices, and tidal turbines, needed to minimize interference of the wake of one turbine with downwind




Fig. 2. New plus existing final nameplate capacity, summed over all WWS electricity generators, when countries in a given region are interconnected versus isolated. Values are from Table 3.






Fig. 3. Percent of all energy produced that is shed when countries in a region are interconnected versus isolated, as found in this study. Values are from Table S9.

turbines. Fig. 4 shows that interconnecting countries slightly reduces the footprint plus spacing land area required in most all cases. The reductions are due to the corresponding reductions in generator nameplate capacity needed (Fig. 2).

The reduction in nameplate capacity and either land or water area needed due to interconnecting countries can be critical to a transition to WWS in some countries. For example, Germany has economic rights to ~56,400 km<sup>2</sup> of offshore water area (10,900 km<sup>2</sup> and 12,500 km<sup>2</sup> within 12 nautical miles of its coasts in the Baltic Sea and North Sea, respectively, and 4500 km<sup>2</sup> and 28,500 km<sup>2</sup> in its Exclusive Economic Zones in the Baltic Sea and North Sea, respectively). With an isolated grid, Germany needs ~94.7 GW of offshore

wind to maintain a stable grid with 100 % WWS in 2050 (Table 3). However, connecting Germany just to Switzerland reduces the offshore wind needs by 20 %, to 75.7 GW (Table 3). With an average European offshore wind installed power density of 7.2 MW/km<sup>2</sup> [41], this translates to a difference between 13,152 km<sup>2</sup> (23.3 %) and 10,513 km<sup>2</sup> (18.6 %) of Germany's available offshore water area for wind turbine spacing. Given that the closer wind farms are packed to each other, the lower their capacity factors [37], the additional 2600 km<sup>2</sup> of open ocean due to interconnecting not only leaves more ocean available for non-energy uses, improves views from the coast, and reduces public objection to offshore wind, but it also increases offshore wind capacity factors.




Fig. 4. Footprint plus spacing land areas needed for new WWS electricity generators when countries in a region are interconnected versus isolated. Values are from Table S16.

A final issue worthy of discussion is whether hydrogen should be used in sectors other than transportation. In previous work [42], we included some hydrogen combustion for high-temperature industrial processes. However, many electric machines that produce high temperatures (arc furnaces, induction furnaces, resistance furnaces, etc.) exist, so it is not clear hydrogen combustion is needed for high temperatures in industry. Further, using electricity to produce hydrogen by electrolysis and more electricity to compress and store and/or transport hydrogen is less efficient than using electricity directly to produce high temperatures. For those reasons, this study assumes the use of electricity instead of electrolytic hydrogen for high temperature processes. On the other hand, hydrogen will be useful for producing steel to almost eliminate process (non-energy) CO<sub>2</sub> emissions from steel production [43]. This process is not treated here.

Another potential use of hydrogen not treated here is for grid electricity. Using electrolytic hydrogen to produce grid electricity is less efficient than using and storing electricity in batteries due to the energy loss involved in producing, compressing, storing, and transporting hydrogen and using hydrogen in a fuel cell. However, a more useful application of stored hydrogen may be for combined electricity and heat production in a fuel cell in remote microgrids [44], but that process was also not treated.

In sum, although we did not treat hydrogen to obtain high temperatures for industry or to produce electric power, such uses of hydrogen are feasible with 100 % WWS, but possibly at a higher cost than using electricity directly.

## Conclusions and implications

In this study, grid stability in the presence of 100 % clean, renewable energy for all purposes was examined in Western European countries when the countries were isolated from each other versus interconnected in various combinations. The study found that all individual countries in Western Europe can provide 100 % of their all-purpose energy from clean, renewable WWS sources within the country. These include the smallest countries, Luxembourg and Gibraltar, as well as large ones. What's more, the annual private cost of WWS energy in all individual countries is 49 %–71 % lower than BAU energy in those countries. The annual social cost of 100 % WWS in those isolated countries is 71 %–90 % lower than in the BAU case in each country. Thus, France, for example, which currently provides 70 % of its electricity from nuclear power, can instead provide 100 % of its all-sector energy from clean, renewable electricity and heat at very low cost. Germany, too, has potential to provide 100 % of its all-purpose energy at low cost from internally-produced WWS.

Interconnecting countries reduces annual costs further by reducing storage requirements and excess generation nameplate capacity. The reductions in both also reduce shedding and land requirements in most cases. Interconnecting Norway, a country with substantial hydropower resources, with other countries, contributes greatly to cost reductions in the other countries. On the other hand, interconnecting small countries, such as Luxembourg and Gibraltar, with larger countries reduces the cost per unit energy and overall energy costs the most in the small countries but also benefits the larger countries. Results here are largely consistent with those from previous studies [3,16,24,27–31] that found smoother, more reliable renewable energy output and lower costs upon interconnecting geographically-dispersed renewables. This study, however, uses a different set of tools (spreadsheet model, weather prediction model, and grid integration model). It also quantifies benefits of such a transition for several combinations of countries in Western Europe not previously examined.

The main implication of this work is that interconnecting

countries can usually serve as an additional benefit to grid stability and cost reduction in a 100 % clean, renewable energy world. Interconnecting two or more isolated grids also hedges against a sudden loss of renewable supply in one isolated grid but not others during an extreme weather event. This benefit is relevant because, even when dominated by fossil fuels, an isolated grid that has no outside electricity support may fail during an extreme weather event, as it did during the February 14–18, 2021 Texas storm. Such an outage could happen in any isolated grid.

Interconnecting countries has political limits. Limits arise if the public doesn't accept too many additional transmission lines. On the other hand, adding transmission may avoid the need to build new WWS generation in a country, reducing objection. Limits can also arise if one country doesn't want to cede too much reliance of its energy security on the goodwill of its neighbors, fearing that a neighbor may shut off the electricity supply during a conflict. This risk must be balanced by the lower cost and increased efficiency of a well-interconnected system.

This study finds that countries can be powered with either locally-produced or geographically-distributed 100 % clean, renewable energy sources. Interconnecting geographically diverse resources across country boundaries reduces aggregate annual energy costs in most, but not all, cases.

## CRediT authorship contribution statement

**Mark Z. Jacobson:** Conceptualization, Methodology, Investigation, Software, Writing – original draft, Writing – review & editing, Visualization.

## Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

## Acknowledgments

This research did not receive any funding from any source. All data from this paper, including data going into all plots, and the LOADMATCH model, are available upon request from jacobson@stanford.edu.

## Appendix A. Supplementary data

Supplementary data to this article can be found online at <https://doi.org/10.1016/j.renene.2021.07.115>.

## References

- [1] REN21 (Renewable Energy Policy Network for the 21st Century), Renewables 2019 global status report, 2019. Table R6, <https://ren21.net/gsr-2019/>. (Accessed 1 December 2020).
- [2] Jacobson, M.Z., 100% Clean, Renewable Energy and Storage for Everything, Cambridge University Press, New York, 427 pp, Table 9.1.
- [3] G. Czisch, Szenarien zur zukünftigen Stromversorgung - Kostenoptimierte Variationen zur Versorgung Europas und seiner Nachbarn mit Strom aus erneuerbaren Energien, Ph.D. Dissertation, University of Kassel, 2005.
- [4] M.Z. Jacobson, M.A. Delucchi, A Path to Sustainable Energy by 2030. Scientific American November, 2009.
- [5] H. Lund, B.V. Mathiesen, Energy system analysis of 100% renewable energy systems-The case of Denmark in years 2030 and 2050, Energy 34 (2009) 524–531.
- [6] I.G. Mason, S.C. Page, A.G. Williamson, A 100% renewable energy generation system for New Zealand utilizing hydro, wind, geothermal, and biomass resources, Energy Pol. 38 (2010) 3973–3984.
- [7] E.K. Hart, M.Z. Jacobson, A Monte Carlo approach to generator portfolio planning and carbon emissions assessments of systems with large penetrations of variable renewables, Renew. Energy 23 (2011) 2278–2286.

- [8] B.V. Mathiesen, H. Lund, K. Karlsson, 100% renewable energy systems, climate mitigation, and economic growth, *Appl. Energy* 88 (2011) 488–501.
- [9] C. Budischak, D. Sewell, H. Thompson, L. Mach, D.E. Veron, W. Kempton, Cost-minimized combinations of wind power, solar power, and electrochemical storage, powering the grid up to 99.9% of the time, *J. Power Sources* 225 (2013) 60–74.
- [10] F. Steinke, P. Wolfrum, C. Hoffmann, Grid vs. storage in a 100% renewable Europe, *Renew. Energy* 50 (2013) 826–832.
- [11] D. Connolly, B.V. Mathiesen, Technical and economic analysis of one potential pathway to a 100% renewable energy system. *Intl. J. Sustain. Energy Plann. Manag.* 1 (2014) 7–28.
- [12] B. Elliston, I. MacGill, M. Diesendorf, Comparing least cost scenarios for 100% renewable electricity with low emission fossil fuel scenarios in the Australian National Electricity Market, *Renew. Energy* 66 (2014) 196–204.
- [13] S. Becker, B.A. Frew, G.B. Andresen, T. Zeyer, S. Schramm, M. Greiner, M.Z. Jacobson, Features of a fully renewable U.S. electricity system: optimized mixes of wind and solar PV and transmission grid extensions, *Energy* 72 (2014) 443–458.
- [14] M.Z. Jacobson, M.A. Delucchi, M.A. Cameron, B.A. Frew, A low-cost solution to the grid reliability problem with 100% penetration of intermittent wind, water, and solar for all purposes, *Proc. Natl. Acad. Sci. Unit. States Am.* 112 (2015) 15,060–15,065.
- [15] B.V. Mathiesen, H. Lund, D. Connolly, H. Wenzel, P.Z. Ostergaard, B. Moller, S. Nielsen, I. Ridjan, P. Karnoe, K. Sperling, F.K. Hvelplund, Smart energy systems for coherent 100% renewable energy and transport solutions, *Appl. Energy* 145 (2015) 139–154.
- [16] D. Bogdanov, C. Breyer, North-East Asian super grid for 100% renewable energy supply: optimal mix of energy technologies for electricity, gas and heat supply options, *Energy Convers. Manag.* 112 (2016) 176–190.
- [17] D. Connolly, H. Lund, B.V. Mathiesen, Smart energy Europe: the technical and economic impact of one potential 100% renewable energy scenario for the European Union, *Renew. Sustain. Energy Rev.* 60 (2016) 1634–1653.
- [18] A. Blakers, B. Lu, M. Socks, 100% renewable electricity in Australia, *Energy* 133 (2017) 417–482.
- [19] S. Zapata, M. Casteneda, M. Jimenez, A.J. Aristizabel, C.J. Franco, I. Dyer, Long-term effects of 100% renewable generation on the Colombian power market, *Sustain. Energy Technol. Assess.* 30 (2018) 183–191.
- [20] M. Esteban, J. Portugal-Pereira, B.C. McLellan, J. Bricker, H. Farzaneh, N. Djalikova, K.N. Ishihara, H. Takagi, V. Roeber, 100% renewable energy system in Japan: smoothening and ancillary services, *Appl. Energy* 224 (2018) 698–707.
- [21] A. Sadiqa, A. Gulagi, C. Breyer, Energy transition roadmap towards 100% renewable energy and role of storage technologies for Pakistan by 2050, *Energy* 147 (2018) 518–533.
- [22] M.Z. Jacobson, M.A. Delucchi, M.A. Cameron, B.V. Mathiesen, Matching demand with supply at low cost among 139 countries within 20 world regions with 100 percent intermittent wind, water, and sunlight (WWS) for all purposes, *Renew. Energy* 123 (2018) 236–248.
- [23] H. Liu, G.B. Andresen, M. Greiner, Cost-optimal design of a simplified highly renewable Chinese network, *Energy* 147 (2018) 534–546.
- [24] A. Aghahosseini, D. Bogdanov, L.S.N.S. Barbosa, C. Breyer, Analyzing the feasibility of powering the Americas with renewable energy and inter-regional grid interconnections by 2030, *Renew. Sustain. Energy Rev.* 105 (2019) 187–205.
- [25] M.Z. Jacobson, M.A. Delucchi, M.A. Cameron, S.J. Coughlin, C. Hay, I.P. Manogaran, Y. Shu, A.-K. von Krauland, Impacts of Green New Deal energy plans on grid stability, costs, jobs, health, and climate in 143 countries, *One Earth* 1 (2019) 449–463.
- [26] D. Bogdanov, A. Toktarova, C. Breyer, Transition towards 100% renewable power and heat supply for energy intensive economics and severe continental climate conditions: case for Kazakhstan, *Appl. Energy* 253 (2019), 113606.
- [27] C.L. Archer, M.Z. Jacobson, Spatial and temporal distributions of U.S. winds and wind power at 80 m derived from measurements, *J. Geophys. Res.* 108 (D9) (2003) 4289, <https://doi.org/10.1029/2002JD002076>.
- [28] C.L. Archer, M.Z. Jacobson, Supplying baseload power and reducing transmission requirements by interconnecting wind farms, *J. Appl. Meteorol. Climatol.* 46 (2007) 1701–1717, <https://doi.org/10.1175/2007JAMC1538.1>.
- [29] A. Blakers, J. Luther, A. Nadolny, Asia Pacific super grid – solar electricity generation, storage and distribution, *Green* 2 (2012) 189–202.
- [30] W.D. Grossman, I. Grossman, K.W. Steininger, Distributed solar electricity generation across large geographic areas, Part I: a method to optimize site selection, generation, and storage, *Renew. Sustain. Energy Rev.* 25 (2013) 831–843.
- [31] A.G. Martin, C. Pozo, A. Azapagic, I.E. Grossmann, N. MacDowell, G. Guillen-Gosalbez, Time for global action: an optimised cooperative approach towards effective climate change mitigation, *Energy Environ. Sci.* 11 (2018) 572–581.
- [32] IEA (International Energy Agency), *World Energy Statistics*, OECD Publishing, Paris, 2018.
- [33] EIA (Energy Information Administration), *U.S. International Energy Outlook*, DOE/EIA-0484, 2016, [http://www.eia.gov/forecasts/ieo/pdf/0484\(2016\).pdf](http://www.eia.gov/forecasts/ieo/pdf/0484(2016).pdf).
- [34] M.Z. Jacobson, On the correlation between building heat demand and wind energy supply and how it helps to avoid blackouts, *Smart Energy* 1 (2021), 100009, <https://doi.org/10.1016/j.segy.2021.100009>.
- [35] M.Z. Jacobson, GATOR-GCMOM: a global through urban scale air pollution and weather forecast model: 1. Model design and treatment of subgrid soil, vegetation, roads, rooftops, water, sea ice, and snow, *J. Geophys. Res.: Atmos.* 106 (2001) 5385–5401.
- [36] M.Z. Jacobson, Y.J. Kaufmann, Y. Rudich, Examining feedbacks of aerosols to urban climate with a model that treats 3-D clouds with aerosol inclusions, *J. Geophys. Res.: Atmos.* 112 (2007), D24205.
- [37] M.Z. Jacobson, C.L. Archer, Saturation wind power potential and its implications for wind energy, *Proc. Natl. Acad. Sci. Unit. States Am.* 109 (2012) 15,679–15,684.
- [38] M.Z. Jacobson, V. Jadhav, World estimates of PV optimal tilt angles and ratios of sunlight incident upon tilted and tracked PV panels relative to horizontal panels, *Sol. Energy* 169 (2018) 55–66.
- [39] ENTSO-E (European Network of Transmission System Operators for Electricity), *European load data*, 2016. <https://www.entsoe.eu/db-query/country-packages/production-consumption-exchange-package>.
- [40] Neocarbon Energy, *Future energy system*, 2016. <http://neocarbonenergy.fi/internetofenergy/>.
- [41] P. Enevoldsen, M.Z. Jacobson, Data investigation of installed and output power densities of onshore and offshore wind turbines worldwide, *Energy Sustain. Develop.* 60 (2021) 40–51.
- [42] M.Z. Jacobson, M.A. Delucchi, G. Bazouin, Z.A.F. Bauer, C.C. Heavey, E. Fisher, S.B. Morris, D.J.Y. Piekutowski, T.A. Vencill, T.W. Yeskoo, 100% clean and renewable wind, water, sunlight (WWS) all-sector energy roadmaps for the 50 United States, *Energy Environ. Sci.* 8 (2015) 2093–2117.
- [43] V. Vogl, M. Ahman, L.J. Nilsson, Assessment of hydrogen direct reduction for fossil-free steelmaking, *J. Clean. Prod.* 203 (2018) 736–745.
- [44] Y. Ali, Sweden's summer sunshine stored in hydrogen for the winter, 2019. <https://microgridknowledge.com/microgrid-hydrogen-sweden/>. (Accessed 29 June 2021).

# **Electronic Supplementary Information**

## **The Cost of Grid Stability With 100% Clean, Renewable Energy for all Purposes When Countries are Isolated Versus Interconnected**

**Mark Z. Jacobson**

This supplementary information file contains additional tables and figures to help explain more fully the methods and results found in this study.

# Supporting Tables

**Table S1.** 1<sup>st</sup> row for each country or region: 2018 annually-averaged total end-use business-as-usual (BAU) load (GW) and percentage of the total load by sector. 2<sup>nd</sup> row: estimated 2050 annually-averaged total end-use load (GW) and percentage of the total load by sector if conventional fossil-fuel, nuclear, and biofuel use continues from today to 2050 under a BAU trajectory. 3<sup>rd</sup> row: estimated 2050 total end-use load (GW) and percent of total load by sector if 100% of BAU end-use all-purpose delivered load in 2050 is instead provided by WWS. The last column shows the percent reductions in total 2050 BAU load due to switching from BAU to WWS, including the effects of reduced energy use due to (a) the higher work to energy ratio of electricity over combustion, (b) eliminating energy use for the upstream mining, transporting, and/or refining of coal, oil, gas, biofuels, bioenergy, and uranium, and (c) policy-driven increases in end-use efficiency beyond those in the BAU case.

Country or region	Scenario	2050 Total end-use load (GW)	Residential percent of total end-use load	Commercial percent of total end-use load	Industrial percent of total end-use load	Transport percent of total end-use load	Ag/For/Fishing percent of total end-use load	Military/other percent of total end-use load	(a) Percent change end-use load w/WWS due to higher work: energy ratio	(b) Percent change end-use load w/WWS due to eliminating upstream	(c) Percent change end-use load w/WWS due to efficiency beyond BAU	Overall percent change in end-use load with WWS
Belgium	BAU 2016	59.96	18.0	10.3	31.8	38.0	1.7	0.11				
	BAU 2050	69.7	18.1	11.5	32.4	36.3	1.6	0.1				
	WWS 2050	29.2	14.1	14.3	48	22.4	1.1	0.03	-43.39	-7.91	-6.81	-58.11
Denmark	BAU 2016	21.5	27.5	12.1	20.0	35.7	4.6	0				
	BAU 2050	25.9	28.9	13.7	21.3	32	4.1	0				
	WWS 2050	9.6	26.9	20.5	26.8	22.3	3.5	0	-47.76	-8.44	-6.64	-62.84
France	BAU 2016	204.6	25.9	15.1	22.6	33.2	2.9	0.41				
	BAU 2050	251.6	26.9	17.5	22.1	30.6	2.5	0.4				
	WWS 2050	112.4	25.3	23.3	29.7	19.8	1.7	0.2	-40.57	-5.86	-8.92	-55.34
Germany	BAU 2016	303.8	24.5	14.8	30.8	29.8	0	0.05				
	BAU 2050	366.4	24.3	16	30.5	29.2	0	0.04				
	WWS 2050	155.2	19.2	19.2	43.2	18.4	0	0.02	-41.69	-8.39	-7.56	-57.64
Gibraltar	BAU 2016	5.14	0	0.026	0.071	99.4	0	0.49				
	BAU 2050	5.43	0	0.044	0.076	99.4	0	0.52				
	WWS 2050	1.31	0	0.142	0.2	98	0	1.68	-69.72	-1.88	-4.17	-75.78
Italy	BAU 2016	165.5	25.8	12.4	26.2	33.2	2.3	0.12				
	BAU 2050	217.4	24.4	13.2	24.3	36.1	1.9	0.1				
	WWS 2050	83.2	19.2	20.3	35.6	23.5	1.5	0	-42.19	-11.58	-7.97	-61.74
Luxembourg	BAU 2016	5.43	12.2	10.3	17.7	59.4	0.49	0				
	BAU 2050	6.04	12.5	11.8	18.1	57.2	0.5	0				
	WWS 2050	2.3	9.7	15.9	36.5	37.6	0.2	0	-52.72	-2.65	-6.61	-61.98
Netherlands	BAU 2016	89.0	14.7	10.1	29.9	39.5	5.8	0.04				
	BAU 2050	105.6	15.5	11.7	31.1	36.4	5.3	0.04				
	WWS 2050	40.1	12.8	17.1	41.3	24.4	4.4	0.02	-45.37	-10.08	-6.6	-62.04
Norway	BAU 2016	33.0	17.2	11.6	47.7	21.9	1.4	0.28				
	BAU 2050	47	17.5	13.2	45.8	22.2	1.1	0.21				
	WWS 2050	20.2	27.2	21.6	38.6	11.3	1.3	0.1	-24.03	-25.15	-7.78	-56.96
Portugal	BAU 2016	24.6	14.1	10.4	33.5	39.6	2.2	0.16				
	BAU 2050	30.3	15.2	13.6	33.7	35.5	1.9	0.13				
	WWS 2050	13.1	17.1	22.1	39.4	20	1.3	0.08	-37.81	-12.06	-6.97	-56.84
Spain	BAU 2016	131.7	15.2	10.7	28.7	42.5	2.7	0.23				
	BAU 2050	165.3	15.6	12.4	29.4	40.1	2.3	0.2				
	WWS 2050	65.7	18.3	19.4	34.8	25.5	1.7	0.3	-39.77	-13.6	-6.89	-60.26
Sweden	BAU 2016	47.6	20.8	12.0	35.6	30.6	0.95	0				
	BAU 2050	58.5	23.4	14.2	32.8	28.9	0.80	0				
	WWS 2050	30.5	24.1	16.9	42.3	16.1	0.6	0	-34.02	-6.45	-7.43	-47.9
Switzerland	BAU 2016	27.7	27.5	16.3	19.3	35.5	0.53	0.91				
	BAU 2050	33.6	27.1	18	18	35.6	0.5	0.80				
	WWS 2050	16	25.4	20.8	27.4	25.5	0.6	0.3	-40.56	-3.25	-8.6	-52.41

United Kingdom	BAU 2016	193.9	26.0	11.3	23.8	37.4	0.79	0.75				
	BAU 2050	233.7	26.9	13	25.1	33.6	0.70	0.68				
	WWS 2050	88.8	24.6	19.6	31.7	23.1	0.73	0.32	-44.32	-9.46	-8.22	-62.0
Nor-Den	BAU 2016	54.5	21.3	11.8	36.8	27.3	2.7	0.17				
	BAU 2050	72.9	21.6	13.4	37.1	25.7	2.2	0.13				
	WWS 2050	29.8	27.1	21.2	34.8	14.8	2.0	0.07	-32.46	-19.21	-7.37	-59.05
Nor-Den-Swe-Ger	BAU 2016	405.9	23.6	14.1	32.2	29.6	0.47	0.06				
	BAU 2050	497.8	23.8	15.4	31.7	28.6	0.4	0.02				
	WWS 2050	215.5	21.0	19.2	41.9	17.6	0.4	0.01	-39.44	-9.75	-7.52	-56.70
Northern Europe	BAU 2016	560.3	21.5	13.0	31.6	32.4	1.4	0.06				
	BAU 2050	679.1	21.8	14.4	31.6	30.9	1.3	0.02				
	WWS 2050	287.1	19.1	18.3	42.4	19.2	1.0	0.01	-33.83	-7.98	-6.27	-48.08
Swi-Fra	BAU 2016	232.3	26.0	15.2	22.2	33.5	2.6	0.47				
	BAU 2050	285.2	26.9	17.6	21.6	31.2	2.3	0.45				
	WWS 2050	128.4	25.3	23.0	29.4	20.5	1.6	0.21	-40.57	-5.55	-8.88	-54.99
Swi-Ger	BAU 2016	331.5	24.7	15.0	29.9	30.3	0.04	0.12				
	BAU 2050	400	24.5	16.2	29.5	29.7	0.0	0.07				
	WWS 2050	171.2	19.8	19.3	41.7	19.1	0.1	0.03	-41.60	-7.96	-7.65	-57.20
Northwest Europe	BAU 2016	792.6	22.8	13.7	28.9	32.7	1.8	0.18				
	BAU 2050	964.3	23.3	15.3	28.6	31.0	1.6	0.15				
	WWS 2050	415.5	21.0	19.8	38.4	19.6	1.2	0.07	-40.79	-8.37	-7.76	-56.92
Swi-Ita	BAU 2016	193.2	26.1	13.0	25.2	33.5	2.1	0.23				
	BAU 2050	251	24.8	13.8	23.5	36.0	1.7	0.19				
	WWS 2050	99.2	20.2	20.4	34.3	23.8	1.4	0.05	-41.97	-10.46	-8.05	-60.49
Spa-Por-Gib	BAU 2016	161.4	14.5	10.3	28.6	43.9	2.5	0.23				
	BAU 2050	201	15.1	12.2	29.3	41.0	2.2	0.19				
	WWS 2050	80.1	17.8	19.5	35.0	25.8	1.6	0.29	-40.28	-13.05	-6.83	-60.16
Western Europe	BAU 2016	1,120	22.1	13.0	28.4	34.4	2.0	0.18				
	BAU 2050	1,383	22.3	14.5	28.0	33.2	1.7	0.15				
	WWS 2050	578.8	20.3	19.8	37.5	21.0	1.3	0.09	-40.94	-9.55	-7.66	-58.15
All Europe	BAU 2016	1,620	23.5	12.2	29.6	32.2	2.3	0.21				
	BAU 2050	2,293	24.4	13.6	28.4	31.5	1.9	0.20				
	WWS 2050	940	22.1	18.9	37.6	19.9	1.3	0.1	-41.6	-9.9	-7.6	-59.0

BAU 2016 values are from IEA (Ref. S2). 2050 BAU values for individual countries are extrapolated from 2016 values, as described in Ref. S1, then summed here for groups of countries. Briefly, EIA's International Energy Outlook (IEO) (Ref. S3) projects energy use by end-use sector, fuel, and 16 world regions out to 2040 in a reference (BAU) scenario that represents modest economic growth. This is extended to 2075 using a ten-year moving linear extrapolation. The EIA projections account for policies, population growth, economic and energy growth, some modest renewable energy additions, and modest energy efficiency measures and reduced energy use in each sector. EIA sectors and fuels are then mapped to IEA sectors and fuels, and each country's 2016 energy consumption by sector and fuel from Ref. 2 is scaled by the ratio of EIA's 2050/2016 energy consumption by sector and fuel for each region. The transportation load includes, among other loads, energy produced in each country for international transportation and shipping. 2050 WWS values are estimated from 2050 BAU values assuming electrification of end-uses and effects of additional energy-efficiency measures beyond those in the BAU case, as discussed in detail in Ref. S1.

**Table S2.** 2050 annual average end-use electric plus heat load (GW) by sector after energy in all sectors has been converted to WWS. Instantaneous loads can be higher or lower than annual average loads.

Country or region	Total	Residential	Commercial	Transport	Industrial	Agriculture/forest/fishing	Military/other
Belgium	29.2	4.11	4.19	6.53	14.03	0.33	0.01
Denmark	9.61	2.58	1.98	2.15	2.58	0.33	0
France	112.4	28.46	26.22	22.23	33.39	1.87	0.21
Germany	155.2	29.79	29.83	28.56	67.02	0	0.03
Gibraltar	1.32	0.00	0.00	1.29	0.00	0	0.02
Italy	83.2	15.94	16.86	19.51	29.60	1.23	0.04
Luxembourg	2.30	0.22	0.37	0.86	0.84	0.01	0
Netherlands	40.1	5.14	6.84	9.77	16.56	1.78	0.01
Norway	20.2	5.49	4.36	2.29	7.81	0.25	0.02
Portugal	13.1	2.24	2.89	2.62	5.15	0.17	0.01
Spain	65.7	12.02	12.73	16.75	22.85	1.15	0.20
Sweden	30.5	7.36	5.16	4.89	12.88	0.19	0
Switzerland	16.0	4.06	3.33	4.08	4.38	0.10	0.05
United Kingdom	88.8	21.81	17.42	20.50	28.15	0.65	0.29
Nor-Den	29.8	8.08	6.33	4.43	10.39	0.59	0.02
Nor-Den-Swe-Ger	215.5	45.22	41.33	37.88	90.29	0.77	0.05
Northern Europe	287.1	54.70	52.72	55.04	121.71	2.88	0.07
Swi-Fra	128.4	32.52	29.55	26.31	37.77	1.97	0.26
Swi-Ger	171.2	33.85	33.16	32.64	71.40	0.10	0.08
Northwest Europe	415.5	87.22	82.27	81.35	159.48	4.85	0.32
Swi-Ita	99.2	20.00	20.19	23.59	33.97	1.33	0.09
Spa-Por-Gib	80.1	14.26	15.62	20.66	28.00	1.31	0.23
Western Europe	578.7	117.4	114.7	121.5	217.1	7.39	0.59
All Europe	939.7	207.2	177.7	187.3	353.7	12.6	1.19

Total values are taken directly from Table S1 and sector values are obtained by multiplying the total by the WWS 2050 percentages in Table S1.



**Table S3.** Annual average WWS all-sector inflexible and flexible loads (GW) in 2050 by country or region. “Total load” is the sum of “inflexible load” and “flexible load.” “Flexible load” is the sum of “cold load subject to storage,” “low-temperature heat load subject to storage,” “load for H<sub>2</sub>” production, compression, and storage (accounting for leaks as well), and “all other loads subject to demand response (DR).” Annual average loads are distributed in time as described in the text. Thus, instantaneous loads, either flexible or inflexible, can be much higher or lower than annual average loads. Also shown is the annual hydrogen mass needed in each region, estimated as the load multiplied by 8,760 hr/yr and divided by 59.01 kWh/kg-H<sub>2</sub>. The last column shows the ratio of WWS:BAU electricity, where WWS electricity is effectively all end-use 2050 WWS energy and BAU electricity is 2050 electricity in the BAU electricity sector.

Country or region	Total end-use load (GW)	Inflexible load (GW)	Flexible load (GW)	Cold load subject to storage (GW)	Low-temperature heat load subject to storage (GW)	Load for H <sub>2</sub> (GW)	All other loads subject to DR (GW)	H <sub>2</sub> needed (Tg-H <sub>2</sub> /yr)	WWS:BAU electricity load
Belgium	29.2	12.9	16.3	0.3	3.0	2.41	10.7	0.36	1.99
Denmark	9.6	3.7	5.9	0.04	2.20	0.80	2.8	0.12	1.62
France	112.4	54.6	57.7	1.44	15.5	6.83	33.9	1.01	1.30
Germany	155.2	71.3	84.0	1.66	20.3	9.36	52.7	1.39	1.58
Gibraltar	1.3	0.2	1.1	0.00	0.00	0.56	0.6	0.08	41.8
Italy	83.2	39.5	43.7	0.99	8.30	5.62	28.8	0.83	1.51
Luxembourg	2.3	0.9	1.4	0.02	0.20	0.34	0.9	0.05	1.99
Netherlands	40.1	18.0	22.1	0.29	4.16	3.78	13.9	0.56	2.01
Norway	20.2	8.8	11.4	0.10	4.14	0.71	6.4	0.11	0.99
Portugal	13.1	6.4	6.7	0.10	1.30	1.02	4.2	0.15	1.52
Spain	65.7	30.3	35.4	1.12	6.25	5.87	22.1	0.87	1.48
Sweden	30.5	12.6	17.9	0.16	5.37	1.36	11.0	0.20	1.32
Switzerland	16.0	7.9	8.1	0.08	1.56	1.02	5.4	0.15	1.40
United Kingdom	88.8	40.3	48.5	0.43	13.0	7.73	27.3	1.15	1.53
Nor-Den	29.8	12.5	17.3	0.14	6.41	1.51	9.3	0.22	1.14
Nor-Den-Swe-Ger	215.5	96.6	118.9	2.04	31.7	12.2	72.9	1.82	1.46
Northern Europe	287.1	128.4	158.7	2.59	39.1	18.8	98.3	2.78	1.57
Swi-Fra	128.4	64.3	64.1	1.25	15.3	7.85	39.7	1.17	1.32
Swi-Ger	171.2	81.5	89.7	1.40	19.4	10.4	58.5	1.54	1.56
Northwest Europe	415.5	190.5	225.0	4.12	56.7	26.6	137.6	3.95	1.48
Swi-Ita	99.2	47.4	51.7	1.06	9.86	6.64	34.2	0.99	1.49
Spa-Por-Gib	80.1	36.9	43.1	1.23	7.54	7.45	26.9	1.11	1.51
Western Europe	578.7	260.9	317.8	7.73	78.2	39.7	192.2	5.89	1.49
All Europe	939.7	423.6	516.1	11.1	133.6	63.3	308.1	9.40	1.51

**Table S4.** Several of the processes treated in the LOADMATCH model.

Parameter	Is the process treated?
Onshore and offshore wind electricity	Yes
Residential, commercial/government rooftop PV electricity	Yes
Utility PV electricity	Yes
CSP electricity	Yes
Geothermal electricity	Yes
Tidal and wave electricity	Yes
Direct solar and geothermal heat	Yes
Battery storage	Yes
CSP storage	Yes
Pumped hydropower storage	Yes
Existing hydropower dam storage	Yes
Added hydropower turbines	No
Heat storage (water tanks, underground)	Yes
Cold storage (water tanks, ice)	Yes
Hydrogen storage in tanks	Yes
Hydrogen fuel cell vehicles for long-distance, heavy transport	Yes
Battery-electric vehicles for all other transport	Yes
District heating	Yes
Electric heat pumps for building cooling and air/water heating	Yes
Electric furnaces and heat pumps for industrial heat	Yes
Wind, PV, CSP, solar heat, wave supply calculated in GATOR-GCMOM	Yes
Building heat and cold loads calculated in GATOR-GCMOM	Yes
Array losses due to wind turbines competing for kinetic energy	Yes
Losses from T&D, storage, shedding, downtime	Yes
Perfect transmission interconnections	Yes
Costs of all generation, all storage, short- and long-distance T&D	Yes
Avoided cost of air pollution damage	Yes
Avoided cost of climate damage	Yes
Land footprint and spacing requirements	Yes
Changes in job numbers	Yes

**Table S5.** LOADMATCH-derived final capacity adjustment factors (CAFs), which are the ratios of the final nameplate capacity of several generators to meet load continuously, after running LOADMATCH, to the pre-LOADMATCH initial nameplate capacity estimated herein (e.g., Table 3 of Ref. S1) to meet load in the annual average. Thus, a CAF less than 1.0 means that the LOADMATCH-stabilized grid meeting hourly demand requires less than the nameplate capacity needed to meet annual average load (which is our initial, pre-LOADMATCH nameplate-capacity assumption). Column (f) is the ratio of CSP turbine nameplate capacity (CSP storage maximum discharge rate) needed to keep the grid stable here relative to the pre-LOADMATCH nameplate capacity estimate for annual average power plus for keeping the grid stable. The pre-LOADMATCH factor is 1.6 (thus an estimated 60% more CSP turbines were added to keep the grid stable). Thus, a number less than 1.6 here indicates fewer CSP turbines are needed compared with the pre-LOADMATCH estimate. Table 3 provides the final CSP nameplate capacity, accounting for this factor. All generators not on this list have a CAF = 1.

Country or region	(a) Onshore wind CAF	(b) Off- shore wind CAF	(c) Res. Roof PV CAF	(d) Com./ Gov Roof PV CAF	(e) Utility PV CAF	(f) CSP turbine factor	(g) Solar Ther mal CAF
Belgium	2	1.8	0.7	0.7	1.3	0	0.019
Denmark	2.5	2.3	0.8	0.8	0.8	0	0.308
France	1.4	0.95	1	1	2.2	0	0.044
Germany	1.5	1.25	1	3	2	0	0.264
Gibraltar	0	0.9	0.8	0.8	0.1	0	0
Italy	1.1	1	0.8	0.8	1.2	1.4	0.132
Luxembourg	4.5	0	1.4	1.5	1	0	0.014
Netherlands	2	1.5	0.7	1.2	1.5	0	0.037
Norway	0.8	0.8	0.5	0.5	0.5	0	0
Portugal	1.35	0.8	0.8	0.8	1.1	1	0.177
Spain	1.3	0.8	0.8	0.8	0.8	1	0.145
Sweden	1	1	0.8	0.8	1	0	0.052
Switzerland	0.5	0	0.5	0.5	0.5	0	0.228
United Kingdom	1.5	1.2	0.8	0.8	1.8	0	0.013
Nor-Den	1	1	0.6	0.6	0.6	0	0.173
Nor-Den-Swe-Ger	1.3	1.2	1	2.8	1.2	0	0.236
Northern Europe	1.5	1.2	1	2.7	1.1	0	0.161
Swi-Fra	1.6	1	1	1	0.9	1	0.066
Swi-Ger	1.5	1	1	2.9	1.5	0	0.261
Northwest Europe	1.3	1.2	1	1	1.2	1	0.133
Swi-Ita	1.1	1	0.8	0.8	1.2	1	0.149
Spa-Por-Gib	1.3	0.8	0.8	0.8	0.8	1	0.15
Western Europe	1.3	1	1	1	1.15	1	0.135
All Europe	1.42	1	0.68	0.9	1	1	0.109

**Table S6.** Average 2050-2052 capacity factors (percent of nameplate capacity produced as electricity before transmission, distribution or maintenance losses) by country or region obtained in this study.

Country or region	On-shore wind	Off-shore wind	Rooftop PV	Utility PV	CSP with storage	Geo-thermal elec-tricity	Hydr opow er	Wave	Tidal	Solar therm al	Geo-thermal heat
Belgium	0.40	0.45	0.18	0.19	--	--	0.77	--	0.25	0.10	0.97
Denmark	0.33	0.39	0.18	0.20	--	--	0.61	0.14	0.24	0.10	0.97
France	0.41	0.51	0.19	0.21	--	0.89	0.59	0.27	0.24	0.10	0.97
Germany	0.35	0.39	0.18	0.19	--	0.91	0.75	0.14	0.25	0.10	0.97
Gibraltar	0.00	0.34	0.24	0.26	--	--	--	0.14	0.29	--	--
Italy	0.38	0.49	0.21	0.24	0.80	0.88	0.56	0.14	0.24	0.12	0.97
Luxembourg	0.37	--	0.18	0.19	--	--	0.49	--	--	0.10	--
Netherlands	0.41	0.44	0.19	0.20	--	--	0.76	--	0.25	0.10	0.97
Norway	0.36	0.39	0.18	0.19	--	--	0.59	0.27	0.24	--	0.97
Portugal	0.35	0.46	0.21	0.25	0.84	0.85	0.48	0.26	0.23	0.12	0.97
Spain	0.37	0.56	0.22	0.26	0.87	0.85	0.49	0.29	0.23	0.12	0.97
Sweden	0.27	0.35	0.18	0.20	--	--	0.70	--	0.25	0.10	0.97
Switzerland	0.38	--	0.19	0.20	--	--	0.82	--	--	0.10	0.97
United Kingdom	0.41	0.48	0.18	0.19	--	--	0.66	0.31	0.24	0.10	0.97
Nor-Den	0.34	0.39	0.18	0.20	--	--	0.63	0.17	0.24	0.10	0.97
Nor-Den-Swe-Ger	0.34	0.38	0.18	0.19	--	0.91	0.70	0.16	0.24	0.10	0.97
Northern Europe	0.34	0.40	0.18	0.19	--	0.91	0.72	0.16	0.24	0.10	0.97
Swi-Fra	0.41	0.51	0.19	0.21	0.70	0.89	0.53	0.27	0.24	0.10	0.97
Swi-Ger	0.35	0.39	0.18	0.19	--	0.91	0.73	0.14	0.25	0.10	0.97
Northwest Europe	0.37	0.42	0.19	0.20	0.70	0.90	0.68	0.23	0.24	0.10	0.97
Swi-Ita	0.38	0.49	0.21	0.23	0.80	0.88	0.53	0.14	0.24	0.11	0.97
Spa-Por-Gib	0.37	0.50	0.22	0.25	0.86	0.85	0.47	0.28	0.23	0.12	0.97
Western Europe	0.37	0.44	0.20	0.21	0.80	0.88	0.62	0.23	0.24	0.11	0.97
All Europe	0.36	0.45	0.20	0.21	0.80	0.86	0.61	0.24	0.24	0.11	0.97

Capacity factors of offshore and onshore wind turbines account for array losses (extraction of kinetic energy by turbines). In all cases, capacity factors are before transmission, distribution, and maintenance losses, which are given in Table S11. The average capacity factor across multiple countries is weighted by the final nameplate capacity (Table 3). The symbol "--" indicates no installation of the technology. Rooftop PV panels are fixed-tilt at the optimal tilt angle of the country they reside in; utility PV panels are half fixed optimal tilt and half single-axis horizontal tracking (Ref. S4).

**Table S7.** Aggregate (among all storage devices in a country or region) maximum instantaneous charge rates, maximum instantaneous discharge rates, and maximum energy storage capacities of the different types of electricity storage (PHS, CSP-PCM, batteries, hydropower), cold storage (CW-STES, ICE), and heat storage (HW-STES, UTES) technologies treated here, by country or region. Table S8 gives the maximum number of hours of storage at the maximum discharge rate. The product of the maximum discharge rate and hours of storage gives the maximum energy storage capacity.

Storage technology	Belgium			Denmark			France			Germany		
	Max charge rate GW	Max discharge rate GW	Max storage capacity TWh	Max charge rate GW	Max discharge rate GW	Max storage capacity TWh	Max charge rate GW	Max discharge rate GW	Max storage capacity TWh	Max charge rate GW	Max discharge rate GW	Max storage capacity TWh
PHS	6.585	6.585	0.092	2	2	0.028	26.45	26.45	0.37	25.82	25.82	0.36
CSP-elec.	0	0	--	0	0	--	0	0	--	0	0	--
CSP-PCM	0	--	0	0	--	0	0	--	0	0	--	0
Batteries	300	300	0.582	200	200	0.388	500	500	0.97	1300	1300	2.522
Hydropower	0.055	0.12	0.484	0.004	0.009	0.036	8.44	18.53	73.96	2.09	4.45	18.30
CW-STES	0.102	0.102	.0014	0.017	0.017	.0002	0.57	0.57	0.008	0.66	0.66	0.009
ICE	0.152	0.152	.0021	0.026	0.026	.0004	0.86	0.86	0.012	1.00	1.00	0.014
HW-STES	8.81	8.81	0.053	4.980	4.980	0.030	47.08	47.08	0.28	60.33	60.33	0.36
UTES-heat	0.334	8.81	3.17	0.894	4.980	1.793	1.63	47.08	5.65	14.04	60.33	14.48
UTES-elec.	13.22	--	--	7.470	--	--	70.62	--	--	90.49	--	--
	Gibraltar			Italy			Luxembourg			Netherlands		
PHS	2	2	0.028	28.44	28.44	0.40	6.54	6.54	0.09	2	2	0.028
CSP-elec.	0	0	--	10.92	10.92	--	0	0	--	0	0	--
CSP-PCM	0	--	0	17.60	--	0.25	0	--	0	0	--	0
Batteries	20	20	0.039	200	200	0.388	120	120	0.233	550	550	1.067
Hydropower	0	0	0	6.48	14.33	56.74	0.016	0.034	0.136	0.017	0.037	0.151
CW-STES	.0001	.0001	.000001	0.40	0.40	0.006	0.008	0.008	.0001	0.116	0.116	0.002
ICE	.0002	.0002	.000003	0.59	0.59	0.008	0.012	0.012	.0002	0.174	0.174	0.002
HW-STES	.0023	.0023	0.00001	24.71	24.71	0.15	0.678	0.678	0.004	10.94	10.94	0.066
UTES-heat	0	.0023	.0008	3.24	24.71	8.90	0.027	0.678	0.813	0.608	10.94	1.313
UTES-elec.	.0034	--	--	37.07	--	--	1.016	--	--	16.41	--	--
	Norway			Portugal			Spain			Sweden		
PHS	6.87	6.87	0.096	11.15	11.15	0.156	13.7	13.7	0.19	2.35	2.35	0.033
CSP-elec.	0	0	--	1.08	1.08	--	5.86	5.86	--	0	0	--
CSP-PCM	0	--	0	1.74	--	0.024	9.44	--	0.13	0	--	0
Batteries	0	0	0	150	150	0.291	50	50	0.097	200	200	0.388
Hydropower	13.9	30.4	121.9	2.060	4.730	18.05	7.45	17.02	65.26	7.60	16.37	66.57
CW-STES	0.039	0.039	0.001	0.039	0.039	0.001	0.45	0.45	0.006	0.064	0.064	.0009
ICE	0.058	0.058	0.001	0.058	0.058	0.001	0.67	0.67	0.009	0.096	0.096	.0013
HW-STES	7.76	7.76	0.047	3.122	3.122	0.019	18.73	18.73	0.11	11.30	11.30	0.07
UTES-heat	0	7.76	0.186	0.677	3.122	2.623	2.84	18.73	6.74	0.34	11.30	10.85
UTES-elec.	11.6	--	--	4.683	--	--	28.10	--	--	16.95	--	--
	Switzerland			United Kingdom			Nor-Den			Nor-Den-Swe-Ger		
PHS	12.7	12.7	0.178	11.6	11.6	0.16	6.87	6.87	0.096	31.0	31.0	0.435
CSP-elec.	0	0	--	0	0	--	0	0	--	0	0	--
CSP-PCM	0	--	0	0	--	0	0	--	0	0	--	0
Batteries	0	0	0	500	500	0.97	0	0	0	1000	1000	1.94
Hydropower	6.29	13.87	55.10	0.83	1.87	7.27	13.9	30.5	121.9	23.6	51.3	206.8
CW-STES	0.033	0.033	.0005	0.17	0.17	0.002	0.057	0.057	0.001	0.81	0.81	0.011
ICE	0.049	0.049	.0007	0.26	0.26	0.004	0.085	0.085	0.001	1.22	1.22	0.017
HW-STES	4.46	4.46	0.03	32.66	32.66	0.20	12.76	12.76	0.077	84.4	84.4	0.506

UTES-heat	1.15	4.46	0.11	0.46	32.66	11.76	0.89	12.76	0.306	15.3	84.4	30.4
UTES-elec.	6.68	--	--	49.00	--	--	19.14	--	--	126.6	--	--
	<b>Northern Europe</b>			<b>Swi-Fra</b>			<b>Swi-Ger</b>			<b>Northwest Europe</b>		
PHS	40.2	40.2	0.562	37.1	37.1	0.520	36.5	36.5	0.511	75.3	75.3	1.05
CSP-elec.	0	0	--	4.51	4.51	--	0	0	--	4.51	4.51	--
CSP-PCM	0	--	0	7.27	--	0.102	0	--	0	7.27	--	0.102
Batteries	1400	1400	2.716	150	150	0.291	1200	1200	2.328	800	800	1.552
Hydropower	23.7	51.5	207.6	14.7	32.4	129.1	8.38	18.32	73.4	38.4	83.9	336.6
CW-STES	1.04	1.04	0.015	0.499	0.499	0.007	0.56	0.56	0.0079	1.6	1.6	0.023
ICE	1.56	1.56	0.022	0.748	0.748	0.011	0.84	0.84	0.012	2.5	2.5	0.035
HW-STES	103.0	103.0	0.618	46.2	46.2	0.277	57.31	57.31	0.34	154.3	154.3	0.926
UTES-heat	16.2	103.0	37.08	2.8	46.2	5.54	15.18	57.31	13.8	19.0	154.3	55.5
UTES-elec.	154.5	--	--	69.2	--	--	85.96	--	--	231.5	--	--
	<b>Swi-Ita</b>			<b>Spa-Por-Gib</b>			<b>Western Europe</b>			<b>All Europe</b>		
PHS	39.1	39.1	0.548	22.8	22.8	0.319	122.5	122.5	1.72	197	197	2.76
CSP-elec.	7.80	7.80	--	6.94	6.94	--	19.2	19.2	--	21.1	21.1	--
CSP-PCM	12.6	--	0.176	11.2	--	0.157	31.0	--	0.434	34.0	--	0.475
Batteries	50	50	0.097	0	0	0	0	0	0	1400	1400	2.716
Hydropower	12.8	28.2	112	9.51	21.75	83.3	54.4	120	477	75.8	167.4	664
CW-STES	0.42	0.42	0.006	0.49	0.49	0.007	3.09	3.09	0.043	4.44	4.44	0.062
ICE	0.63	0.63	0.009	0.74	0.74	0.010	4.64	4.64	0.065	6.66	6.66	0.093
HW-STES	28.4	28.4	0.17	21.0	21.0	0.13	212	212	1.27	337	337	2.02
UTES-heat	4.38	28.4	13.63	3.52	21.0	10.1	25.8	212	76.3	36.7	337	202
UTES-elec.	42.6	--	--	31.5	--	--	318	--	--	505	--	--

PHS = pumped hydropower storage; PCM = Phase-change materials; CSP=concentrated solar power; CW-STES = Chilled-water sensible heat thermal energy storage; HW-STES = Hot water sensible heat thermal energy storage; and UTES = Underground thermal energy storage (either boreholes, water pits, or aquifers). The peak energy storage capacity equals the maximum discharge rate multiplied by the maximum number of hours of storage at the maximum discharge rate. Table S8 gives maximum storage times at the maximum discharge rate.

Heat captured in a working fluid by a CSP solar collector can be either used immediately to produce electricity by evaporating water and running it through a steam turbine connected to a generator, stored in a phase-change material, or both. The maximum direct CSP electricity production rate (CSP-elec) equals the maximum electricity discharge rate, which equals the nameplate capacity of the generator. The maximum charge rate of CSP phase-change material storage (CSP-PCM) is set to 1.612 multiplied by the maximum electricity discharge rate, which allows more energy to be collected than discharged directly as electricity. Thus, since the high-temperature working fluid in the CSP plant can be used to produce electricity and charge storage at the same time, the maximum overall electricity production plus storage charge rate of energy is 2.612 multiplied by the maximum discharge rate. This ratio is also the ratio of the mirror size with storage versus without storage. This ratio can be up to 3.2 in existing CSP plants. The maximum energy storage capacity equals the maximum electricity discharge rate multiplied by the maximum number of hours of storage at full discharge, set to 22.6 hours, or 1.612 multiplied by the 14 hours required for CSP storage to charge when charging at its maximum rate.

Hydropower's maximum discharge rate in 2050 is its 2018 nameplate capacity. Hydropower can be charged only naturally by rainfall and runoff, but its annual-average charge rate must equal at least its annual energy output divided by the number of hours per year. It is assumed simplistically that hydro is recharged at that rate, and that its annual energy output (TWh/yr) in 2050 is close to its 2018 output. It is further assumed that the maximum hydropower energy storage capacity available in reservoirs equals hydro's annual energy output, and this energy is recharged each year by rainfall and runoff. Whereas the present table gives hydro's maximum storage capacity, its output from storage during a given time step is limited by the smallest among three factors: the current energy available in the reservoir, the peak hydro discharge rate multiplied by the time step, and the energy needed during the time step to keep the grid stable.

The CW-STES charge/discharge rate is set equal to 40% of the maximum daily averaged cold load subject to storage.

The ICE storage charge/discharge rate is set to 60% of the same peak cold load subject to storage.

The HW-STES peak discharge rate is set equal to the maximum instantaneous heat load subject to storage during any 30-second period of the two-year simulation. The values have been converted to electricity assuming the heat needed for storage is produced by heat pumps (with a coefficient of performance of 4) running on electricity. Because peak discharge rates are based on maximum rather than the annual average loads, they are higher than the annual-average low-temperature heat loads subject to storage in Table S3. The peak charge rate is set equal to the peak discharge rate.

UTES heat stored in underground soil (borehole storage) or water (water pit or aquifer storage) can be charged with either solar or geothermal heat or excess electricity (assuming the electricity produces heat with an electric heat pump at a coefficient of performance of 4). The maximum charge rate of heat (converted to equivalent electricity) to UTES storage (UTES-heat) is set to the nameplate capacity of solar thermal collectors divided by the coefficient of performance of a heat pump=4). In several countries and regions, no solar thermal collectors are used. When no solar thermal collectors are used, the maximum charge rate for UTES-heat is zero, and UTES is charged only with excess grid electricity running heat pumps. The maximum charge rate of excess grid electricity converted to heat stored in UTES (UTES-elec.) is set by trial and error for each country or region. The maximum UTES heat discharge rate is set equal to the maximum instantaneous heat load subject to storage. The maximum charge rate, discharge rate, and capacity of UTES storage are all in units of equivalent electricity that would give heat at a coefficient of performance of 4.

**Table S8.** Maximum number of hours or days of storage at the maximum discharge rate of each storage type (given in Table S7 for each country or region). The maximum discharge rate multiplied by the number of hours of storage equals the maximum storage capacity in Table S7. For all regions, the maximum CSP storage time at the maximum discharge rate is 22.6 h; that for PHS storage is 14 h; that for HW-STES storage is 6 h; that for CW-STES storage is 6 h; that for ICE storage is 14 h; and that for battery storage is 1.94 h.

Country or region	UTES (day)	H <sub>2</sub> (day)
Belgium	15	15
Denmark	15	15
France	5	5
Germany	10	5
Gibraltar	15	15
Italy	15	15
Luxembourg	50	50
Netherlands	5	10
Norway	1	1
Portugal	35	35
Spain	15	25
Sweden	40	5
Switzerland	1	1
United Kingdom	15	15
Nor-Den	1	1
Nor-Den-Swe-Ger	15	20
Northern Europe	15	17
Swi-Fra	5	10
Swi-Ger	10	10
Northwest Europe	15	15
Swi-Ita	20	25
Spa-Por-Gib	20	20
Western Europe	15	15
All Europe	25	5



**Table S9.** Budgets of WWS end-use energy demand met, energy losses, energy supplies, and changes in storage, during the 1-year (8,747.4875 hour) simulations here for all 24 countries/regions. All units are TWh over the 1-year simulation. Divide TWh by the number of hours of simulation to obtain annual-average power values (TW). Table 1 identifies the countries within each region. Figure S1 shows the time series of matching demand with supply and changes in storage for each country or region.

	<b>Bel- gium</b>	<b>Den- mark</b>	<b>France</b>	<b>Ger- many</b>	<b>Gib- raltar</b>
<b>A1. Total end use demand</b>	<b>255</b>	<b>84</b>	<b>983</b>	<b>1,358</b>	<b>12</b>
Electricity for electricity inflexible demand	116	33	488	634	2
Electricity for electricity, heat, cold storage + DR	119	44	435	642	5
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	21	7	60	82	5
<b>A2. Total end use demand</b>	<b>255</b>	<b>84</b>	<b>983</b>	<b>1,358</b>	<b>12</b>
Electricity for direct use, electricity storage, + H <sub>2</sub>	231	65	846	1,178	11
Low-T heat load met by heat storage	24	19	135	178	0
Cold load met by cold storage	0.34	0.17	1.86	2.33	0.00
<b>A3. Total end use demand</b>	<b>255</b>	<b>84</b>	<b>983</b>	<b>1,358</b>	<b>12</b>
Electricity for direct use, electricity storage, DR	206	58	775	1,084	7
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	21	7	60	82	5
Electricity + heat for heat subject to storage	26	19	136	178	0
Electricity for cold load subject to storage	2.22	0.37	12.56	14.52	0.00
<b>B. Total losses</b>	<b>141</b>	<b>60</b>	<b>446</b>	<b>876</b>	<b>7</b>
Transmission, distribution, downtime losses	29	10	91	134	1
Losses CSP storage	0.00	0.00	0.00	0.00	0.00
Losses PHS storage	3.8	0.5	10.8	12.8	0.2
Losses battery storage	4	0.5	1.65	17.7	0.0
Losses CW-STES + ICE storage	0	0.0	0.34	0.4	0.0
Losses HW-STES storage	3	2.8	22	26.4	0.0
Losses UTES storage	5	3.6	15	32.3	0.0
Losses from shedding	96	42	305	653	5
<b>Net end-use demand plus losses (A1 + B)</b>	<b>397</b>	<b>144</b>	<b>1,429</b>	<b>2,234</b>	<b>18</b>
<b>C. Total WWS supply before T&amp;D losses</b>	<b>393</b>	<b>145</b>	<b>1,427</b>	<b>2,236</b>	<b>18</b>
Onshore + offshore wind electricity	152	117	731	1,053	18
Rooftop + utility PV+ CSP electricity	240	25	582	1,143	0
Hydropower electricity	1	0	96	29	0
Wave electricity	0	1	10	1	0
Geothermal electricity	0	0	0.271	0.255	0
Tidal electricity	0.008	0.155	2.121	0.077	0.003
Solar heat	0.074	0.196	0.373	3.107	0
Geothermal heat	0.439	0.751	4.994	6.061	0
<b>D. Net taken from (+) or added to (-) storage</b>	<b>3.24</b>	<b>-0.253</b>	<b>2.319</b>	<b>-1.887</b>	<b>-0.015</b>
CSP storage	0	0	0	0	0
PHS storage	-0.009	-0.003	-0.037	-0.036	0.002
Battery storage	-0.058	-0.039	-0.097	-0.252	-0.004
CW-STES+ICE storage	0	0	-0.002	-0.002	0
HW-STES storage	-0.005	-0.003	0.117	-0.036	0
UTES storage	2.643	-0.179	2.109	-1.448	0
H <sub>2</sub> storage	0.67	-0.029	0.23	-0.112	-0.013
<b>Energy supplied plus taken from storage (C+D)</b>	<b>397</b>	<b>144</b>	<b>1,429</b>	<b>2,234</b>	<b>18</b>
	<b>Italy</b>	<b>Lux- embourg</b>	<b>Neth- erlands</b>	<b>Norway</b>	<b>Por- tugal</b>
<b>A1. Total end use demand</b>	<b>728</b>	<b>20</b>	<b>351</b>	<b>177</b>	<b>114</b>

Electricity for electricity inflexible demand	352	8	160	103	57
Electricity for electricity, heat, cold storage + DR	326	9	158	68	48
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	49	3	33	6	9
<b>A2. Total end use demand</b>	<b>728</b>	<b>20</b>	<b>351</b>	<b>177</b>	<b>114</b>
Electricity for direct use, electricity storage, + H <sub>2</sub>	654	18	314	170	104
Low-T heat load met by heat storage	73	2	36	7	11
Cold load met by cold storage	1.03	0.02	0.38	0.17	0.13
<b>A3. Total end use demand</b>	<b>728</b>	<b>20</b>	<b>351</b>	<b>177</b>	<b>114</b>
Electricity for direct use, electricity storage, DR	597	15	279	134	93
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	49	3	33	6	9
Electricity + heat for heat subject to storage	73	2	36	36	11
Electricity for cold load subject to storage	8.65	0.17	2.53	0.85	0.85
<b>B. Total losses</b>	<b>194</b>	<b>8</b>	<b>228</b>	<b>20</b>	<b>22</b>
Transmission, distribution, downtime losses	60	2	43	14	8
Losses CSP storage	0.26	0.00	0.00	0.00	0.03
Losses PHS storage	8.7	1.1	1.0	0.1	1.7
Losses battery storage	1	0.02	6	0.0	0.05
Losses CW-STES + ICE storage	0	0.00	0	0.0	0.02
Losses HW-STES storage	10	0.12	5	0.9	1.13
Losses UTES storage	15	0.71	6	0.2	3.03
Losses from shedding	98	4	167	4.7	7.2
<b>Net end-use demand plus losses (A1 + B)</b>	<b>921</b>	<b>28</b>	<b>579</b>	<b>197.1</b>	<b>135.8</b>
<b>C. Total WWS supply before T&amp;D losses</b>	<b>917</b>	<b>27</b>	<b>579</b>	<b>197</b>	<b>132</b>
Onshore + offshore wind electricity	471	6	310	25	60
Rooftop + utility PV+ CSP electricity	362	20	267	11	50
Hydropower electricity	70	0	0	156	20
Wave electricity	3	0	0	1	1
Geothermal electricity	7.697	0	0	0	0.741
Tidal electricity	0.157	0	0.026	0.744	1.014
Solar heat	0.817	0.006	0.135	0	0.174
Geothermal heat	2.158	0	1.681	2.766	0.075
<b>D. Net taken from (+) or added to (-) storage</b>	<b>4.574</b>	<b>1.276</b>	<b>-0.338</b>	<b>0.313</b>	<b>3.309</b>
CSP storage	0.121	0	0	0	0.019
PHS storage	0.203	0.034	-0.003	0.087	0.137
Battery storage	-0.039	0.207	-0.107	0	0.001
CW-STES+ICE storage	-0.001	0	0	0.001	0.001
HW-STES storage	0.133	0.004	-0.007	0.042	0.017
UTES storage	2.337	0.665	-0.131	0.168	2.36
H <sub>2</sub> storage	1.82	0.365	-0.091	0.015	0.773
<b>Energy supplied plus taken from storage (C+D)</b>	<b>921</b>	<b>28</b>	<b>579</b>	<b>197.1</b>	<b>135.8</b>

	Spain	Sweden	Switzerland	United Kingdom	Nor-Den
<b>A1. Total end use demand</b>	<b>575</b>	<b>267</b>	<b>140</b>	<b>777</b>	<b>261</b>
Electricity for electricity inflexible demand	272	115	79	356	146
Electricity for electricity, heat, cold storage + DR	251	140	52	354	101
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	51	12	9	68	13
<b>A2. Total end use demand</b>	<b>575</b>	<b>267</b>	<b>140</b>	<b>777</b>	<b>261</b>
Electricity for direct use, electricity storage, + H <sub>2</sub>	518	224	137	663	247
Low-T heat load met by heat storage	55	43	3	114	14
Cold load met by cold storage	1.80	0.20	0.00	0.60	0.13
<b>A3. Total end use demand</b>	<b>575</b>	<b>267</b>	<b>140</b>	<b>777</b>	<b>261</b>

Electricity for direct use, electricity storage, DR	459	206	117	592	190
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	51	12	9	68	13
Electricity + heat for heat subject to storage	55	47	14	114	56
Electricity for cold load subject to storage	9.78	1.39	0.72	3.80	1.24
<b>B. Total losses</b>	<b>143</b>	<b>38</b>	<b>12</b>	<b>467</b>	<b>26</b>
Transmission, distribution, downtime losses	46	21	10	88	21
Losses CSP storage	0.13	0.00	0.00	0.00	0.00
Losses PHS storage	4.5	1.1	1.1	5.1	1.1
Losses battery storage	0	0	0.00	5.63	0.00
Losses CW-STES + ICE storage	0	0	0.00	0.11	0.02
Losses HW-STES storage	9	3	0.03	18.24	1.84
Losses UTES storage	7	11	0.09	17.46	0.80
Losses from shedding	76	2	0	332	2
<b>Net end-use demand plus losses (A1 + B)</b>	<b>717</b>	<b>305</b>	<b>152.0</b>	<b>1,244</b>	<b>286.9</b>
<b>C. Total WWS supply before T&amp;D losses</b>	<b>711</b>	<b>295</b>	<b>152</b>	<b>1,237</b>	<b>286</b>
Onshore + offshore wind electricity	382	116	22	609	80
Rooftop + utility PV+ CSP electricity	247	67	27	585	33
Hydropower electricity	74	100	99	11	168
Wave electricity	5	0	0	8	1
Geothermal electricity	0.373	0	0	0	0
Tidal electricity	2.038	0.217	0	23.593	0.899
Solar heat	0.758	0.073	0.256	0.098	0.193
Geothermal heat	0.136	11.915	3.688	0.604	3.517
<b>D. Net taken from (+) or added to (-) storage</b>	<b>5.988</b>	<b>10.053</b>	<b>0.303</b>	<b>6.939</b>	<b>0.466</b>
CSP storage	0.04	0	0	0	0
PHS storage	0.053	0.03	0.16	-0.016	0.087
Battery storage	-0.01	0.049	0	-0.097	0
CW-STES+ICE storage	-0.001	0.002	0.001	-0.001	0.002
HW-STES storage	0.101	0.061	0.024	-0.02	0.069
UTES storage	2.637	9.764	0.096	4.612	0.276
H <sub>2</sub> storage	3.168	0.147	0.022	2.46	0.033
<b>Energy supplied plus taken from storage (C+D)</b>	<b>717</b>	<b>305</b>	<b>152.0</b>	<b>1,244</b>	<b>286.9</b>

	<b>Nor-Den-Swe-Ger</b>	<b>North-ern Europe</b>	<b>Swi-Fra</b>	<b>Swi-Ger</b>	<b>North-west Europe</b>
<b>A1. Total end use demand</b>	<b>1,885</b>	<b>2,512</b>	<b>1,123</b>	<b>1,498</b>	<b>3,635</b>
Electricity for electricity inflexible demand	861	1,139	570	722	1,700
Electricity for electricity, heat, cold storage + DR	918	1,208	484	685	1,702
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	107	164	69	91	233
<b>A2. Total end use demand</b>	<b>1,885</b>	<b>2,512</b>	<b>1,123</b>	<b>1,498</b>	<b>3,635</b>
Electricity for direct use, electricity storage, + H <sub>2</sub>	1,608	2,166	988	1,326	3,142
Low-T heat load met by heat storage	274	342	134	170	488
Cold load met by cold storage	3.16	3.98	1.58	1.46	5.02
<b>A3. Total end use demand</b>	<b>1,885</b>	<b>2,512</b>	<b>1,123</b>	<b>1,498</b>	<b>3,635</b>
Electricity for direct use, electricity storage, DR	1,483	1,984	909	1,225	2,870
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	107	164	69	91	233
Electricity + heat for heat subject to storage	277	342	134	170	496
Electricity for cold load subject to storage	17.81	22.68	10.91	12.27	36.02
<b>B. Total losses</b>	<b>720</b>	<b>977</b>	<b>412</b>	<b>773</b>	<b>1,030</b>

Transmission, distribution, downtime losses	158	222	97	133	308
Losses CSP storage	0.00	0.00	0.09	0.00	0.11
Losses PHS storage	15.7	20.1	11.5	18.2	35.1
Losses battery storage	5.29	12.16	0.26	12.71	8.70
Losses CW-STES + ICE storage	0.57	0.72	0.29	0.26	0.91
Losses HW-STES storage	36.89	46.78	22.08	24.10	66.86
Losses UTES storage	49.67	63.58	13.94	32.67	86.78
Losses from shedding	454	611	266	551	523
<b>Net end-use demand plus losses (A1 + B)</b>	<b>2,605</b>	<b>3,489</b>	<b>1,535</b>	<b>2,271</b>	<b>4,664</b>
<b>C. Total WWS supply before T&amp;D losses</b>	<b>2,582</b>	<b>3,466</b>	<b>1,535</b>	<b>2,272</b>	<b>4,615</b>
Onshore + offshore wind electricity	1,191	1,666	891	1,054	2,316
Rooftop + utility PV+ CSP electricity	1,047	1,443	473	1,087	1,746
Hydropower electricity	315	325	149	117	501
Wave electricity	3	3	10	1	13
Geothermal electricity	0.255	0.255	0.271	0.255	0.527
Tidal electricity	1.192	1.226	2.121	0.077	3.347
Solar heat	3.367	3.586	0.632	3.364	4.237
Geothermal heat	21.494	23.613	8.681	9.749	32.295
<b>D. Net taken from (+) or added to (-) storage</b>	<b>23.319</b>	<b>22.505</b>	<b>-0.042</b>	<b>-1.945</b>	<b>48.806</b>
CSP storage	0	0	-0.01	0	-0.01
PHS storage	-0.043	-0.056	-0.052	-0.051	-0.105
Battery storage	-0.194	-0.272	-0.029	-0.233	-0.155
CW-STES+ICE storage	-0.003	-0.004	-0.002	-0.002	-0.006
HW-STES storage	-0.051	-0.062	0.094	-0.034	-0.093
UTES storage	19.174	17.455	-0.554	-1.375	41.019
H <sub>2</sub> storage	4.436	5.444	0.511	-0.249	8.156
<b>Energy supplied plus taken from storage (C+D)</b>	<b>2,605</b>	<b>3,489</b>	<b>1,535</b>	<b>2,271</b>	<b>4,664</b>

	Swi-Ita	Spa-Por-Gib	West-ern Europe	All Europe
<b>A1. Total end use demand</b>	<b>868</b>	<b>700</b>	<b>5,063</b>	<b>8,221</b>
Electricity for electricity inflexible demand	422	330	2,334	3,803
Electricity for electricity, heat, cold storage + DR	388	305	2,382	3,864
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	58	65	347	554
<b>A2. Total end use demand</b>	<b>868</b>	<b>700</b>	<b>5,063</b>	<b>8,221</b>
Electricity for direct use, electricity storage, + H <sub>2</sub>	780	632	4,371	7,069
Low-T heat load met by heat storage	86	66	680	1,136
Cold load met by cold storage	1.16	1.99	11.68	15.33
<b>A3. Total end use demand</b>	<b>868</b>	<b>700</b>	<b>5,063</b>	<b>8,221</b>
Electricity for direct use, electricity storage, DR	714	559	3,965	6,401
Electricity for H <sub>2</sub> direct use + H <sub>2</sub> storage	58	65	347	554
Electricity + heat for heat subject to storage	86	66	684	1,169
Electricity for cold load subject to storage	9.26	10.72	67.60	97.17
<b>B. Total losses</b>	<b>202</b>	<b>161</b>	<b>1,365</b>	<b>1,995</b>
Transmission, distribution, downtime losses	69	55	416	668
Losses CSP storage	0.20	0.16	0.45	0.48
Losses PHS storage	12.2	6.0	49.8	79.4
Losses battery storage	0.40	0.00	0.00	8
Losses CW-STES + ICE storage	0.21	0.36	2.11	3
Losses HW-STES storage	11.40	10.17	101.84	160
Losses UTES storage	18.06	9.71	93.84	181

Losses from shedding	90	80	700	896
<b>Net end-use demand plus losses (A1 + B)</b>	<b>1,069</b>	<b>861</b>	<b>6,427</b>	<b>10,216</b>
<b>C. Total WWS supply before T&amp;D losses</b>	<b>1,061</b>	<b>851</b>	<b>6,355</b>	<b>10,040</b>
Onshore + offshore wind electricity	519	456	3,190	5,457
Rooftop + utility PV+ CSP electricity	393	293	2,440	3,545
Hydropower electricity	132	90	646	895
Wave electricity	3	7	22	32
Geothermal electricity	7.697	1.114	9.338	23.859
Tidal electricity	0.157	3.055	6.558	30.991
Solar heat	1.085	0.933	5.973	8.505
Geothermal heat	5.845	0.211	34.663	47.501
<b>D. Net taken from (+) or added to (-) storage</b>	<b>8.186</b>	<b>10.007</b>	<b>72.856</b>	<b>175.868</b>
CSP storage	0.086	0.045	-0.043	-0.048
PHS storage	0.223	0.024	-0.172	-0.276
Battery storage	-0.01	0	0	-0.272
CW-STES+ICE storage	-0.001	-0.001	-0.011	-0.016
HW-STES storage	0.153	0.114	0.509	-0.202
UTES storage	4.15	6.609	59.72	169.845
H <sub>2</sub> storage	3.585	3.217	12.852	6.836
<b>Energy supplied plus taken from storage (C+D)</b>	<b>1,069</b>	<b>861</b>	<b>6,427</b>	<b>10,216</b>

End-use demands in A1, A2, A3 should be identical. Table S10 gives round-trip storage efficiencies. Table S11 gives transmission/distribution/maintenance losses as a percent of energy generated by a source. Generated electricity is shed when it exceeds the sum of electricity demand, cold storage capacity, heat storage capacity, and H<sub>2</sub> storage capacity. Onshore and offshore wind turbines in GATOR-GCMOM are assumed to be Senvion (formerly Repower) 5 MW turbines with 126-m diameter rotors, 100 m hub heights, a cut-in wind speed of 3.5 m/s, and a cut-out wind speed of 30 m/s. Rooftop PV panels in GATOR-GCMOM are modeled as fixed-tilt panels at the optimal tilt angle of the country they resided in; utility PV panels are modeled as half fixed optimal tilt and half single-axis horizontal tracking. All panels are assumed to have a nameplate capacity of 390 W and a panel area of 1.629668 m<sup>2</sup>, which gives a 2050 panel efficiency (Watts of power output per Watt of solar radiation incident on the panel) of 23.9%, which is an increase from the 2015 value of 20.1%. Each CSP plant before storage is assumed to have the mirror and land characteristics of the Ivanpah solar plant, which has 646,457 m<sup>2</sup> of mirrors and 2.17 km<sup>2</sup> of land per 100 MW nameplate capacity and a CSP efficiency (fraction of incident solar radiation that is converted to electricity) of 15.796%, calculated as the product of the reflection efficiency of 55% and the steam plant efficiency of 28.72%. The efficiency of the solar thermal for heat hot fluid collection (energy in fluid divided by incident radiation) is assumed to be 34%.

**Table S10.** Present value of the mean 2019 to 2050 lifecycle costs of new storage capacity and round-trip efficiencies of the storage technologies treated here.

Storage technology	Present-value of lifecycle cost of new storage (\$/kWh-max energy storage capacity)			Round-trip charge/store/discharge efficiency (percent)
	Middle	Low	High	
<b>Electricity</b>				
PHS	14	12	16	80
CSP-PCM	20	15	23	55, 28.72, 99
LI Batteries	60	30	90	85
<b>Cold</b>				
CW-STES	6.5	0.13	12.9	84.7
ICE	36.7	12.9	64.5	82.5
<b>Heat</b>				
HW-STES	6.5	0.13	12.9	83
UTES	0.90	0.071	1.71	56

From Ref. S1.

PHS = pumped hydropower storage; CSP-PCM = concentrated solar power with phase change material for storage; LI Batteries = lithium ion batteries; CW-STES = cold water sensible-heat thermal energy storage; ICE = ice storage; HW-STES = hot water sensible-heat thermal energy storage; UTES = underground thermal energy storage (modeled as borehole). PHS efficiency is the ratio of electricity delivered to the sum of electricity delivered and electricity used to pump the water.

Storage costs per unit energy generated in the overall system of each storage technology are calculated as the product of the maximum energy storage capacity (Table S7) and the lifecycle-averaged capital cost of storage per unit maximum energy storage capacity (this table), annualized with the same discount rate as for power generators (Table S11, footnote), but with 2050 storage lifetimes of 17 (12 to 22) years for batteries and 32.5 (25 to 40) years all other storage, all divided by the annual average end-use load met.

The CSP-PCM cost is for the PCM material and storage tanks. In the model, only the heat captured by the working fluid due to reflection of sunlight off of CSP mirrors can be stored. The three CSP-PCM efficiencies are as follows. 55% of incoming sunlight is reflected to the central tower, where it is absorbed by the working fluid (the remaining 45% of sunlight is lost to reflection and absorption by the CSP mirrors); without storage, 28.72% of heat absorbed by the working fluid is converted to electricity (the remaining 71.28% of heat is lost); and with storage, 99% of heat received by the working fluid that goes into storage is recovered and available to the steam turbine after storage (Mancini, 2006) and, of that, 28.72% is converted to electricity. Thus, the overall efficiency of CSP without storage is 15.785% and that with storage is 15.638%.

**Table S11.** Parameters for determining costs of energy from electricity and heat generators.

	Capital cost new installations (\$Million/MW)	O&M Cost (\$/kW/yr)	Decommissioning cost (% of capital cost)	Lifetime (years)	TDM losses (% of energy generated)
Onshore wind	1.27 (1.07-1.47)	37.5 (35-40)	1.25 (1.2-1.3)	30 (25-35)	7.5 (5-10)
Offshore wind	1.86 (1.49-2.24)	80 (60-100)	2 (2-2)	30 (25-35)	7.5 (5-10)
Residential PV	2.97 (2.65-3.28)	27.5 (25-30)	0.75 (0.5-1)	44 (41-47)	1.5 (1-2)
Commercial/government PV	2.06 (1.80-2.31)	16.5 (13-20)	0.75 (0.5-1)	46 (43-49)	1.5 (1-2)
Utility-scale PV	1.32 (1.16-1.49)	19.5 (16.5-22.5)	0.75 (0.5-1)	48.5 (45-52)	7.5 (5-10)
CSP with storage <sup>a</sup>	4.84 (4.42-5.26)	50 (40-60)	1.25 (1-1.5)	45 (40-50)	7.5 (5-10)
Geothermal for electricity	3.83 (2.47-5.18)	45 (36-54)	2.5 (2-3)	45 (40-50)	7.5 (5-10)
Hydropower	2.81 (2.38-3.25)	15.5 (15-16)	2.5 (2-3)	85 (70-100)	7.5 (5-10)
Wave	4.01 (2.74-5.28)	175 (100-250)	2 (2-2)	45 (40-50)	7.5 (5-10)
Tidal	3.57 (2.85-4.29)	125 (50-200)	2.5 (2-3)	45 (40-50)	7.5 (5-10)
Solar thermal for heat	1.22 (1.12-1.33)	50 (40-60)	1.25 (1-1.5)	35 (30-40)	3 (2-4)
Geothermal for heat	3.83 (2.47-5.18)	45 (36-54)	2 (1-3)	45 (40-50)	7.5 (5-10)

From Ref. S1. 1 Euro = 1 USD on March 1, 2021.

Capital costs (per MW of nameplate capacity) are an average of 2019 and 2050. O&M=Operation and maintenance.

TDM = transmission/distribution/maintenance. TDM losses are a percentage of all energy produced by the generator and are an average over short and long-distance (high-voltage direct current) lines.

Short-distance transmission costs are \$0.0105 (0.01-0.011)/kWh.

Distribution costs are \$0.02375 (0.023-0.0245)/kWh.

Long-distance transmission costs are \$0.00406 (0.00152-0.00903)/kWh (in USD 2013) (Ref. S1), which assumes 1,200 to 2,000 km lines. It is assumed that 30% of all annually-averaged electricity generated is subject to long-distance transmission in all multi-country regions; 15% of all electricity is subject to long-distance transmission in Germany, the UK, France, Norway, Sweden, Spain, Portugal, and Italy; 10% is subject to long-distance transmission in Denmark, the Netherlands, Belgium, and Switzerland; and 0% is subject to long-distance transmission in Luxembourg and Gibraltar.

The discount rate used for generation, storage, transmission/distribution, and social costs is a social discount rate of 2 (1-3)% (Ref. S1).

<sup>a</sup>The capital cost of CSP with storage includes the cost of extra mirrors and land but excludes costs of phase-change material and storage tanks, which are given in Table S10. The cost of CSP with storage depends on the ratio of the CSP storage maximum charge rate plus direct electricity use rate (which equals the maximum discharge rate) to the CSP maximum discharge rate. For the purpose of benchmarking the “CSP with storage” cost in this table, we use a ratio of 3.2:1. (In other words, if 3.2 units of sunlight come in, a maximum of 2.2 units can go to storage and a maximum of 1 unit can be discharged directly as electricity at the same time.) The ratio for “CSP no storage” is 1:1. In our actual simulations and cost calculations, we assume a ratio of 2.61:1 for CSP with storage<sup>1</sup> and find the cost for this assumed ratio by interpolating between the “CSP with storage” benchmark value and the “CSP no storage” value in this table.

**Table S12.** Parameters in the calculation of the value of statistical life over time and by country.

Parameter	LCHB	Middle	HCLB
U.S. VOSL in base year 2006 ( $VOSL_{US,BY}$ ) (\$mil/death USD 2006)	9.00	7.00	5.00
U.S. VOSL in target year 2050 ( $VOSL_{US,Y}$ ) (\$mil/death USD 2013)	15.37	10.40	6.47
2006 global average VOSL (\$mil/death USD 2006)	4.00	3.48	3.43
2050 global average VOSL (\$mil/death USD 2013)	8.15	7.09	6.99
U.S. GDP per capita in 2006 ( $G_{US,BY}$ ) (USD \$/person 2006)	52,275	52,275	52,275
U.S. GDP per capita target year 2050 ( $G_{US,Y}$ ) (USD \$/person 2013)	96,093	96,093	96,093
Multiplier for morbidity impacts ( $F_1$ )	1.25	1.15	1.05
Multiplier for non-health impacts ( $F_2$ )	1.10	1.10	1.05
Fractional reduction in mortalities per year ( $\Delta A_c$ )	-0.014	-0.015	-0.016
Exponent giving change in mortality with population change ( $\kappa$ )	1.14	1.11	1.08
Fraction of country's VOSL fixed at U.S. TY value ( $T$ )	0.10	0.00	0.00
GDP/capita elasticity ( $\gamma_{GDP,US,BY}$ ) of VOSL, U.S. base year 2006	0.75	0.50	0.25
GDP/capita elasticity ( $\gamma_{GDP}$ ) of VOSL, all years	-0.15	-0.15	-0.15

These parameters, from Ref. S1, are applied to the equations in Note S39 of Ref. S1. LCHB = low cost, high benefit. HCLB = high cost, low benefit. VOSL = value of statistical life. GDP = gross domestic product at purchasing power parity (PPP). Multiply LCHB VOSL by the high estimate of air pollution premature deaths to obtain the high estimate of air pollution cost in the BAU case (or greatest avoided air pollution benefit in the WWS case). 1 Euro = 1 USD on March 1, 2021.



**Table S13.** Low, mid, and high estimates of the social cost of carbon (SCC).

Parameter	Low estimate	Mid estimate	High estimate
2010 Global SCC (2007 USD)	125	250	600
Annual percentage increase in SCC	1.8	1.5	1.2
2050 Global SCC (2013 USD)	282	500	1,063

Units of the SCC are USD per metric tonne-CO<sub>2</sub>e. These parameters are derived from the sources discussed in Note S40 of Ref. S1. 1 Euro = 1 USD on March 1, 2021.

**Table S14.** Summary of 2050 WWS mean capital costs of new electricity plus heat generators and storage (\$ trillion in 2013 USD) and mean levelized private costs of energy (LCOE) (USD ¢/kWh-all-energy or ¢/kWh-electricity-replacing-BAU-electricity) averaged over each simulation for each country or region (defined in Table 1). Also shown are the energy consumed per year in each case and the resulting aggregate annual energy cost to the country or region. 1 Euro = 1 USD on March 1, 2021.

	Belgium	Denmark	France	Germany	Gibraltar	Italy	Luxembourg
Capital cost new generators only (\$trillion)	0.25	0.076	0.87	1.56	0.012	0.49	0.019
Cap cost generators-storage-H <sub>2</sub> -HVDC (\$trillion)	0.30	0.11	0.98	1.78	0.017	0.57	0.039
<i>Components of total LCOE (¢/kWh-all-energy)</i>							
Short-dist. transmission	1.05	1.05	1.05	1.05	1.05	1.05	1.05
Long-distance transmission	0.04	0.04	0.06	0.06	0.00	0.06	0.00
Distribution	2.38	2.38	2.38	2.38	2.38	2.38	2.38
Electricity generators	5.43	6.59	5.01	6.55	7.81	4.20	4.70
Additional hydro turbines	0	0	0	0	0	0	0
Solar thermal collectors	0.03	0.17	0.06	0.13	0.00	0.06	0.01
CSP-PCM+PHS+battery storage	1.18	2.38	0.52	0.96	1.91	0.34	6.19
CW-STES+ICE storage	0.002	0.001	0.003	0.002	0.000	0.003	0.002
HW-STES storage	0.008	0.013	0.011	0.010	0.000	0.008	0.008
UTES storage	0.06	0.11	0.03	0.05	0.00	0.06	0.21
H <sub>2</sub> production/compression/storage	0.32	0.32	0.14	0.14	1.64	0.26	1.35
<b>Total LCOE (¢/kWh-all-energy)</b>	<b>10.5</b>	<b>13.0</b>	<b>9.26</b>	<b>11.3</b>	<b>14.8</b>	<b>8.42</b>	<b>15.9</b>
LCOE (¢/kWh-replacing BAU electricity)	10.1	12.6	9.07	11.1	13.1	8.09	14.3
GW annual avg. end-use demand (Table S3)	29.2	9.61	112	155	1.32	83.2	2.30
TWh/y end-use demand (GW x 8,760 h/y)	256	84	984	1,360	12	729	20
<b>Annual energy cost (\$billion/yr)</b>	<b>26.9</b>	<b>11.0</b>	<b>91.1</b>	<b>154</b>	<b>1.7</b>	<b>61.4</b>	<b>3.2</b>
	Netherlands	Norway	Portugal	Spain	Sweden	Switzerland	United Kingdom
Capital cost new generators only (\$trillion)	0.34	0.026	0.069	0.35	0.12	0.035	0.76
Cap cost generators-storage-H <sub>2</sub> -HVDC (\$trillion)	0.42	0.03	0.10	0.41	0.16	0.040	0.88
<i>Components of total LCOE (¢/kWh-all-energy)</i>							
Short-dist. transmission	1.05	1.05	1.05	1.05	1.05	1.05	1.05
Long-distance transmission	0.04	0.06	0.06	0.06	0.06	0.04	0.06
Distribution	2.38	2.38	2.38	2.38	2.38	2.38	2.38
Electricity generators	5.78	2.38	3.92	3.99	3.41	2.20	5.72
Additional hydro turbines	0	0	0	0	0	0	0
Solar thermal collectors	0.05	0.12	0.06	0.05	0.36	0.28	0.01
CSP-PCM+PHS+battery storage	1.55	0.03	1.40	0.13	0.75	0.08	0.65
CW-STES+ICE storage	0.002	0.001	0.002	0.004	0.001	0.001	0.001
HW-STES storage	0.007	0.010	0.006	0.007	0.009	0.007	0.009
UTES storage	0.02	0.01	0.12	0.06	0.21	0.00	0.08
H <sub>2</sub> production/compression/storage	0.29	0.06	0.54	0.48	0.10	0.11	0.34
<b>Total LCOE (¢/kWh-all-energy)</b>	<b>11.2</b>	<b>6.10</b>	<b>9.54</b>	<b>8.21</b>	<b>8.33</b>	<b>6.15</b>	<b>10.3</b>
LCOE (¢/kWh-replacing BAU electricity)	10.9	6.03	8.87	7.66	8.01	6.02	9.87
GW annual avg. end-use demand (Table S3)	40.1	20.2	13.1	65.7	30.5	16.0	88.8
TWh/y end-use demand (GW x 8,760 h/y)	351	177	114	575	267	140	778
<b>Annual energy cost (\$billion/yr)</b>	<b>39.2</b>	<b>10.8</b>	<b>10.9</b>	<b>47.2</b>	<b>22.2</b>	<b>8.6</b>	<b>80.1</b>
	NorDen	NorDen-Swe-Ger	North-ern Europe	Swi-Fra	Swi-Ger	North-west Europe	Swi-Ita
Capital cost new generators only (\$trillion)	0.068	1.59	2.10	0.87	1.53	2.60	0.55
Cap cost generators-storage-H <sub>2</sub> -HVDC (\$trillion)	0.084	1.89	2.51	0.98	1.80	3.04	0.66
<i>Components of total LCOE (¢/kWh-all-energy)</i>							
Short-dist. transmission (¢/kWh-all-energy)	1.05	1.05	1.05	1.05	1.05	1.05	1.05
Long-distance transmission	0.12	0.12	0.12	0.12	0.12	0.12	0.12
Distribution	2.38	2.38	2.38	2.38	2.38	2.38	2.38
Electricity generators	2.81	5.17	5.10	4.64	5.89	4.47	4.02
Additional hydro turbines	0	0	0	0	0	0	0
Solar thermal collectors	0.14	0.16	0.13	0.08	0.14	0.12	0.10
CSP-PCM+PHS+battery storage	0.02	0.54	0.56	0.17	0.81	0.24	0.12

CW-STES+ICE storage	0.001	0.002	0.002	0.002	0.002	0.002	0.002
HW-STES storage	0.011	0.010	0.009	0.009	0.009	0.010	0.007
UTES storage	0.01	0.08	0.08	0.03	0.05	0.08	0.08
H <sub>2</sub> production/compression/storage	0.09	0.26	0.27	0.19	0.19	0.25	0.36
<b>Total LCOE (¢/kWh-all-energy)</b>	<b>6.63</b>	<b>9.77</b>	<b>9.70</b>	<b>8.66</b>	<b>10.6</b>	<b>8.71</b>	<b>8.23</b>
LCOE (¢/kWh-replacing BAU electricity)	6.51	9.41	9.33	8.43	10.4	8.36	7.77
GW annual avg. end-use demand (Table S3)	29.8	215.5	287.1	128.4	171.2	415.5	99.2
TWh/y end-use demand (GW x 8,760 h/y)	261	1,888	2,515	1,124	1,500	3,640	869
Annual energy cost (\$billion/yr)	<b>17.3</b>	<b>184.4</b>	<b>243.9</b>	<b>97.4</b>	<b>159.6</b>	<b>316.9</b>	<b>71.5</b>
	Spa- Por- Gib	West- ern Europe	All Europe				
Capital cost new generators only (\$trillion)	0.42	3.54	5.49				
Cap cost generators-storage-H <sub>2</sub> -HVDC (\$trillion)	0.51	4.04	6.41				
<i>Components of total LCOE (¢/kWh-all-energy)</i>							
Short-dist. transmission (¢/kWh-all-energy)	1.05	1.05	1.05				
Long-distance transmission	0.12	0.12	0.12				
Distribution	2.38	2.38	2.38				
Electricity generators	4.01	4.37	4.18				
Additional hydro turbines	0	0	0				
Solar thermal collectors	0.05	0.10	0.09				
CSP-PCM+PHS+battery storage	0.05	0.03	0.19				
CW-STES+ICE storage	0.003	0.003	0.003				
HW-STES storage	0.007	0.009	0.009				
UTES storage	0.07	0.08	0.13				
H <sub>2</sub> production/compression/storage	0.43	0.26	0.16				
<b>Total LCOE (¢/kWh-all-energy)</b>	<b>8.17</b>	<b>8.39</b>	<b>8.30</b>				
LCOE (¢/kWh-replacing BAU electricity)	7.65	8.04	8.00				
GW annual avg. end-use demand (Table S3)	80.1	578.7	939.7				
TWh/y end-use demand (GW x 8,760 h/y)	701	5,070	8,232				
Annual energy cost (\$billion/yr)	<b>57.3</b>	<b>425.6</b>	<b>683.7</b>				

Capital costs per new nameplate capacity of generators are given in Table S11.

Capital costs per new storage capacity of storage devices are given in Table in Table S10.

H<sub>2</sub> costs are derived as in Note S38 and Note S43 of Ref. S1. These costs exclude electricity costs, which are included separately in the present table.

Short- and long-distance transmission costs and distribution costs per unit energy are given in Table S11 (footnotes).

The “Capital cost of generators-storage-H<sub>2</sub>-HVDC (\$trillion)” is the capital cost of new electricity and heat generators; electricity, heat, cold, and hydrogen storage devices; hydrogen electrolyzers and compressors; and long-distance (HVDC) transmission.

The LCOEs of electricity generators are derived from assumed capital costs, annual O&M costs, lifetimes, and end-of-life decommissioning costs, that vary with technology, and a social discount rate, all given in Table S11, together with the total annualized end-use demand met, given in the present table. LCOEs of storage options

Since the total end-use load includes heat, cold, hydrogen, and electricity loads (all energy), the “electricity generator” cost, for example, is a cost per unit all energy rather than per unit electricity alone. The ‘Total LCOE’ gives the overall cost of energy, and the ‘Electricity LCOE’ gives the cost of energy for the electricity portion of load replacing BAU electricity end use. It is the total LCOE less the costs for UTES and HW-STES storage, H<sub>2</sub>, and less the portion of long-distance transmission associated with H<sub>2</sub>.

**Table S15.** Private and social costs for each country or region. This is the 2050 country- or regional average WWS versus BAU mean social cost per unit energy. Also shown is the WWS-to-BAU aggregate social cost ratio and the components of its derivation.

	Belgium	Denmark	France	Germany	Gibraltar	Italy
a) BAU electricity private cost per unit energy (€/kWh) <sup>1</sup>	11.1	12.6	9.39	10.9	10.8	11.1
b) BAU health cost per unit energy (€/kWh)	3.83	4.61	4.67	6.22	0.46	8.87
c) BAU climate cost per unit energy (€/kWh)	11.3	9.80	10.2	16.4	0.9	12.5
<b>d) BAU social cost per unit energy (€/kWh) (a+b+c)</b>	<b>26.2</b>	<b>27.0</b>	<b>24.2</b>	<b>33.5</b>	<b>12.2</b>	<b>32.5</b>
<b>e) WWS private and social cost per unit energy (€/kWh)<sup>1</sup></b>	<b>10.5</b>	<b>13.0</b>	<b>9.26</b>	<b>11.3</b>	<b>14.8</b>	<b>8.42</b>
f) BAU end-use power demand (GW) <sup>2</sup>	69.7	25.9	251.6	366.4	5.4	217.4
g) WWS end-use power demand (GW) <sup>2</sup>	29.2	9.6	112.4	155.2	1.3	83.2
h) BAU aggregate annual energy private cost (\$bil/yr) (af)	67.9	28.6	207	348	5.2	211
i) BAU health cost (\$bil/yr) (bf)	23.4	10.4	103	200	0.2	169
j) BAU climate cost (\$bil/yr) (cf)	68.9	22.2	224	527	0.4	239
<b>k) BAU social cost (\$bil/yr) (df)</b>	<b>160</b>	<b>61.2</b>	<b>534</b>	<b>1,075</b>	<b>5.8</b>	<b>618</b>
<b>l) WWS private and social cost (\$bil/yr) (eg)</b>	<b>26.8</b>	<b>11.0</b>	<b>91.1</b>	<b>154</b>	<b>1.7</b>	<b>61.4</b>
m) WWS-to-BAU energy private cost/kWh ratio (R <sub>WWS,BAU-E</sub> ) (e/a)	0.94	1.03	0.99	1.04	1.36	0.76
n) BAU-energy-private-to-social-cost/kWh ratio (R <sub>BAU-S:E</sub> ) (a/d)	0.42	0.47	0.39	0.32	0.89	0.34
o) WWS-kWh-used-to-BAU-kWh-used ratio (R <sub>WWS,BAU-C</sub> ) (g/f)	0.42	0.37	0.45	0.42	0.24	0.38
<b>WWS-to-BAU aggregate social cost ratio (R<sub>ASC</sub>) (mno)</b>	<b>0.17</b>	<b>0.18</b>	<b>0.17</b>	<b>0.14</b>	<b>0.29</b>	<b>0.10</b>
<b>WWS-to-BAU aggregate private cost ratio (R<sub>APC</sub>) (mo)</b>	<b>0.40</b>	<b>0.38</b>	<b>0.44</b>	<b>0.44</b>	<b>0.33</b>	<b>0.29</b>
<b>WWS-to-BAU social cost per unit energy ratio (R<sub>SCE</sub>) (mn)</b>	<b>0.40</b>	<b>0.48</b>	<b>0.38</b>	<b>0.34</b>	<b>1.21</b>	<b>0.26</b>

	Luxembourg	Netherlands	Norway	Portugal	Spain	Sweden
a) BAU electricity private cost per unit energy (€/kWh) <sup>1</sup>	12.0	11.2	6.61	10.9	10.8	8.70
b) BAU health cost per unit energy (€/kWh)	2.68	3.87	1.67	5.27	5.49	2.02
c) BAU climate cost per unit energy (€/kWh)	11.9	12.5	7.5	14.2	12.9	6.6
<b>d) BAU social cost per unit energy (€/kWh) (a+b+c)</b>	<b>26.6</b>	<b>27.5</b>	<b>15.8</b>	<b>30.3</b>	<b>29.2</b>	<b>17.3</b>
<b>e) WWS private and social cost per unit energy (€/kWh)<sup>1</sup></b>	<b>15.9</b>	<b>11.2</b>	<b>6.10</b>	<b>9.54</b>	<b>8.21</b>	<b>8.33</b>
f) BAU end-use power demand (GW) <sup>2</sup>	6.0	105.7	47.0	30.3	165.3	58.5
g) WWS end-use power demand (GW) <sup>2</sup>	2.3	40.1	20.2	13.1	65.7	30.5
h) BAU aggregate annual energy private cost (\$bil/yr) (af)	6.3	103	27.2	28.9	157	44.6
i) BAU health cost (\$bil/yr) (bf)	1.4	35.8	6.9	14.0	79	10.4
j) BAU climate cost (\$bil/yr) (cf)	6.3	116	31.0	37.5	186	33.7
<b>k) BAU social cost (\$bil/yr) (df)</b>	<b>14.1</b>	<b>255</b>	<b>65.1</b>	<b>80.4</b>	<b>423</b>	<b>88.6</b>
<b>l) WWS private and social cost (\$bil/yr) (eg)</b>	<b>3.2</b>	<b>39.2</b>	<b>10.8</b>	<b>10.9</b>	<b>47.2</b>	<b>22.2</b>
m) WWS-to-BAU energy private cost/kWh ratio (R <sub>WWS,BAU-E</sub> ) (e/a)	1.33	1.00	0.92	0.88	0.76	0.96
n) BAU-energy-private-to-social-cost/kWh ratio (R <sub>BAU-S:E</sub> ) (a/d)	0.45	0.41	0.42	0.36	0.37	0.50
o) WWS-kWh-used-to-BAU-kWh-used ratio (R <sub>WWS,BAU-C</sub> ) (g/f)	0.38	0.38	0.43	0.43	0.40	0.52
<b>WWS-to-BAU aggregate social cost ratio (R<sub>ASC</sub>) (mno)</b>	<b>0.23</b>	<b>0.15</b>	<b>0.17</b>	<b>0.14</b>	<b>0.11</b>	<b>0.25</b>
<b>WWS-to-BAU aggregate private cost ratio (R<sub>APC</sub>) (mo)</b>	<b>0.51</b>	<b>0.38</b>	<b>0.40</b>	<b>0.38</b>	<b>0.30</b>	<b>0.50</b>
<b>WWS-to-BAU social cost per unit energy ratio (R<sub>SCE</sub>) (mn)</b>	<b>0.60</b>	<b>0.41</b>	<b>0.39</b>	<b>0.31</b>	<b>0.28</b>	<b>0.48</b>

	Switzerland	United Kingdom	NorDen	NorDen-Swe-Ger	North-ern Europe	Swi-Fra
a) BAU electricity private cost per unit energy (€/kWh) <sup>1</sup>	7.79	11.2	8.74	10.3	10.5	9.20
b) BAU health cost per unit energy (€/kWh)	4.22	6.7	2.71	5.21	4.84	4.62
c) BAU climate cost per unit energy (€/kWh)	8.9	12.3	8.3	14.1	13.5	10.0
<b>d) BAU social cost per unit energy (€/kWh) (a+b+c)</b>	<b>20.9</b>	<b>30.1</b>	<b>19.8</b>	<b>29.6</b>	<b>28.9</b>	<b>23.8</b>

<b>e) WWS private and social cost per unit energy (€/kWh)<sup>1</sup></b>	<b>6.15</b>	<b>10.3</b>	<b>6.63</b>	<b>9.77</b>	<b>9.70</b>	<b>8.66</b>
f) BAU end-use power demand (GW) <sup>2</sup>	33.6	233.7	72.8	497.8	679.2	285.2
g) WWS end-use power demand (GW) <sup>2</sup>	16.0	88.8	29.8	215.5	287.1	128.4
h) BAU aggregate annual energy private cost (\$bil/yr) (af)	22.9	228	55.8	449	626	230
i) BAU health cost (\$bil/yr) (bf)	12.4	137	17.3	227	288	115
j) BAU climate cost (\$bil/yr) (cf)	26.3	251	53.2	614	805	250
<b>k) BAU social cost (\$bil/yr) (df)</b>	<b>61.6</b>	<b>616</b>	<b>126</b>	<b>1,290</b>	<b>1,719</b>	<b>595</b>
<b>l) WWS private and social cost (\$bil/yr) (eg)</b>	<b>8.6</b>	<b>80.1</b>	<b>17.3</b>	<b>184</b>	<b>244</b>	<b>97</b>
m) WWS-to-BAU energy private cost/kWh ratio ( $R_{WWS:BAU-E}$ ) (e/a)	0.79	0.92	0.76	0.95	0.92	0.94
n) BAU-energy-private-to-social-cost/kWh ratio ( $R_{BAU-S:E}$ ) (a/d)	0.37	0.37	0.44	0.35	0.36	0.39
o) WWS-kWh-used-to-BAU-kWh-used ratio ( $R_{WWS:BAU-C}$ ) (g/f)	0.48	0.38	0.41	0.43	0.42	0.45
<b>WWS-to-BAU aggregate social cost ratio (<math>R_{ASC}</math>) (mno)</b>	<b>0.14</b>	<b>0.13</b>	<b>0.14</b>	<b>0.14</b>	<b>0.14</b>	<b>0.16</b>
<b>WWS-to-BAU aggregate private cost ratio (<math>R_{APC}</math>) (mo)</b>	<b>0.38</b>	<b>0.35</b>	<b>0.31</b>	<b>0.41</b>	<b>0.39</b>	<b>0.42</b>
<b>WWS-to-BAU social cost per unit energy ratio (<math>R_{SCE}</math>) (mn)</b>	<b>0.29</b>	<b>0.34</b>	<b>0.33</b>	<b>0.33</b>	<b>0.34</b>	<b>0.36</b>

	Swi-Ger	North-west Europe	Swi-Ita	Spa-Por-Gib	Western Europe	All Europe
a) BAU electricity private cost per unit energy (€/kWh) <sup>1</sup>	10.6	10.1	10.6	10.8	10.4	10.3
b) BAU health cost per unit energy (€/kWh)	6.05	4.77	8.25	5.32	5.50	7.91
c) BAU climate cost per unit energy (€/kWh)	15.8	12.5	12.1	12.7	12.5	13.6
<b>d) BAU social cost per unit energy (€/kWh) (a+b+c)</b>	<b>32.4</b>	<b>27.4</b>	<b>30.9</b>	<b>28.9</b>	<b>28.4</b>	<b>31.8</b>
<b>e) WWS private and social cost per unit energy (€/kWh)<sup>1</sup></b>	<b>10.6</b>	<b>8.71</b>	<b>8.23</b>	<b>8.17</b>	<b>8.39</b>	<b>8.30</b>
f) BAU end-use power demand (GW) <sup>2</sup>	400.1	964.4	251.0	201.0	1,383	2,293
g) WWS end-use power demand (GW) <sup>2</sup>	171.2	415.5	99.2	80.1	578.7	939.7
h) BAU aggregate annual energy private cost (\$bil/yr) (af)	371	856	234	191	1,258	2,076
i) BAU health cost (\$bil/yr) (bf)	212	403	181	94	666	1,588
j) BAU climate cost (\$bil/yr) (cf)	553	1,054	265	224	1,518	2,723
<b>k) BAU social cost (\$bil/yr) (df)</b>	<b>1,136</b>	<b>2,314</b>	<b>680</b>	<b>509</b>	<b>3,441</b>	<b>6,387</b>
<b>l) WWS private and social cost (\$bil/yr) (eg)</b>	<b>160</b>	<b>317</b>	<b>71</b>	<b>57</b>	<b>426</b>	<b>684</b>
m) WWS-to-BAU energy private cost/kWh ratio ( $R_{WWS:BAU-E}$ ) (e/a)	1.00	0.86	0.77	0.75	0.81	0.80
n) BAU-energy-private-to-social-cost/kWh ratio ( $R_{BAU-S:E}$ ) (a/d)	0.33	0.37	0.34	0.38	0.37	0.33
o) WWS-kWh-used-to-BAU-kWh-used ratio ( $R_{WWS:BAU-C}$ ) (g/f)	0.43	0.43	0.40	0.40	0.42	0.41
<b>WWS-to-BAU aggregate social cost ratio (<math>R_{ASC}</math>) (mno)</b>	<b>0.14</b>	<b>0.14</b>	<b>0.11</b>	<b>0.11</b>	<b>0.12</b>	<b>0.11</b>
<b>WWS-to-BAU aggregate private cost ratio (<math>R_{APC}</math>) (mo)</b>	<b>0.43</b>	<b>0.37</b>	<b>0.31</b>	<b>0.30</b>	<b>0.34</b>	<b>0.33</b>
<b>WWS-to-BAU social cost per unit energy ratio (<math>R_{SCE}</math>) (mn)</b>	<b>0.33</b>	<b>0.32</b>	<b>0.27</b>	<b>0.28</b>	<b>0.30</b>	<b>0.26</b>

<sup>1</sup>This is the BAU electricity-sector cost of energy per unit energy. It is assumed to equal the BAU all-energy cost of energy per unit energy. The WWS cost per unit energy is for all energy, which is almost all electricity (plus a small amount of direct heat).

<sup>2</sup>Multiply GW by 8,760 hr/yr to obtain GWh/yr.

**Table S16.** Footprint and spacing areas. Footprint areas are for new utility PV farms, CSP plants, solar thermal plants for heat, geothermal plants for electricity and heat, and hydropower plants. Spacing areas are for new onshore wind turbines. Solar PV footprint can reside within onshore wind spacing areas.

Country or region	Region land area (km <sup>2</sup> )	Footprint Area (km <sup>2</sup> )	Spacing area (km <sup>2</sup> )	Land footprint area as percentage of country/region land area (%)	Land spacing area as a percentage of country/region land area (%)
Belgium	30,280	1,658	505	5.48	1.67
Denmark	42,430	111	1,168	0.26	2.75
France	547,561	2,022	7,508	0.37	1.37
Germany	348,540	3,876	9,462	1.11	2.71
Gibraltar	7	0.15	0	2.15	0.00
Italy	294,140	998	4,574	0.34	1.55
Luxembourg	2,590	138	95	5.34	3.68
Netherlands	33,720	1,752	896	5.20	2.66
Norway	365,268	40	204	0.01	0.06
Portugal	91,590	110	571	0.12	0.62
Spain	498,800	480	3,582	0.10	0.72
Sweden	407,340	351	1,306	0.09	0.32
Switzerland	39,516	66	328	0.17	0.83
United Kingdom	241,930	3,581	2,937	1.48	1.21
Nor-Den	407,698	130	608	0.03	0.15
Nor-Den-Swe-Ger	1,163,578	2,880	10,533	0.25	0.91
Northern Europe	1,230,168	5,438	13,681	0.44	1.11
Swi-Fra	587,077	1,050	9,750	0.18	1.66
Swi-Ger	388,056	3,053	10,454	0.79	2.69
Northwest Europe	1,817,245	7,354	19,142	0.40	1.05
Swi-Ita	333,656	1,087	5,300	0.33	1.59
Spa-Por-Gib	590,397	568	4,129	0.10	0.70
Western Europe	2,701,782	8,679	28,772	0.32	1.06
All Europe	5,671,860	13,207	54,362	0.23	0.96

Spacing areas are areas between wind turbines needed to avoid interference of the wake of one turbine with the next. Such spacing area can be used for multiple purposes, including farmland, rangeland, open space, or utility PV. Footprint areas are the physical land areas, water surface areas, or sea floor surface areas removed from use for any other purpose by an energy technology. Rooftop PV is not included in the footprint calculation because it does not take up new land. Conventional hydro new footprint is zero because no new dams are proposed as part of these roadmaps. Offshore wind, wave, and tidal are not included in the spacing area calculation because they don't take up new land. Table S25 of Ref. S1 gives the installed power densities assumed here as follows: Onshore wind: 19.8 MW/km<sup>2</sup> (land spacing)<sup>S5</sup>; offshore wind (ocean spacing): 7.2 MW/km<sup>2</sup> (ocean spacing)<sup>S5</sup>; utility PV (footprint): 81.8 MW/km<sup>2</sup>; and CSP (footprint): 34.1 MW/km<sup>2</sup>. The onshore and offshore wind installed power densities originate from Ref. S5. Areas are given both as an absolute area and as a percentage of the country or region land area, which excludes inland or coastal water bodies. For comparison, the total area and land area of Earth are 510.1 and 144.6 million km<sup>2</sup>, respectively.

**Table S17. Changes in the Numbers of Long-Term, Full-Time Jobs**

Estimated numbers of long-term, full-time jobs created and lost due to transitioning from BAU energy to WWS across all energy sectors. The job creation numbers account for new jobs in the electricity, heat, cold, and hydrogen generation, storage, and transmission (including HVDC transmission) industries. However, they do not account for changes in jobs in the production of electric appliances, vehicles, and machines or in increasing building energy efficiency. Construction jobs are for new WWS devices only. Operation jobs are for new and existing devices. The losses are due to eliminating jobs for mining, transporting, processing, and using fossil fuels, biofuels, and uranium. Fossil-fuel jobs due to non-energy uses of petroleum, such as lubricants, asphalt, petrochemical feedstock, and petroleum coke, are retained. For transportation sectors, the jobs lost are those due to transporting fossil fuels (e.g., through truck, train, barge, ship, or pipeline); the jobs not lost are those for transporting other goods. The table does not account for jobs lost in the manufacture of combustion appliances, including automobiles, ships, or industrial machines.


Country or region	Construction jobs produced	Operation jobs produced	Total jobs produced	Jobs lost	Net change in jobs
Belgium	132,726	207,167	339,893	49,524	290,369
Denmark	48,160	83,886	132,046	34,109	97,937
France	357,356	422,364	779,720	194,522	585,198
Germany	676,656	879,068	1,555,724	287,543	1,268,181
Gibraltar	7,707	5,645	13,353	3,089	10,264
Italy	219,065	238,394	457,460	151,359	306,101
Luxembourg	24,108	37,464	61,572	3,374	58,198
Netherlands	167,991	294,911	462,902	105,769	357,133
Norway	18,855	25,168	44,023	182,642	-138,619
Portugal	49,338	65,039	114,377	32,381	81,996
Spain	141,639	157,701	299,340	119,419	179,921
Sweden	65,987	105,556	171,542	67,585	103,957
Switzerland	23,791	24,901	48,693	25,773	22,920
United Kingdom	309,306	485,881	795,186	231,372	563,814
Nor-Den	36,416	50,975	87,391	216,751	-129,360
Nor-Den-Swe-Ger	682,560	817,565	1,500,125	571,879	928,246
Northern Europe	909,377	1,185,268	2,094,645	730,546	1,364,099
Swi-Fra	335,700	318,126	653,826	220,295	433,531
Swi-Ger	670,514	824,005	1,494,519	313,316	1,181,203
Northwest Europe	1,060,421	1,320,577	2,380,998	950,841	1,430,157
Swi-Ita	231,610	240,444	472,054	177,132	294,922
Spa-Por-Gib	174,570	185,191	359,761	154,889	204,872
Western Europe	1,359,513	1,552,650	2,912,163	1,257,089	1,655,074
All Europe	2,261,735	2,770,760	5,032,495	2,176,604	2,855,891

## Supporting Figures


**Figure S1.** 2050 time-series comparison for 21 of the 24 countries/regions defined in Table 1. First row: modeled time-dependent total WWS power generation versus load plus losses plus changes in storage plus shedding. Second row: same as first row, but for a window of 100 days during the year. Third row: a breakdown of WWS power generation by source during the window. Fourth row: a breakdown of inflexible load; flexible electric, heat, and cold load; flexible hydrogen load; losses in and out of storage; transmission and distribution losses; changes in storage; and shedding during the window. The model was run at 30-s resolution. Results are shown hourly. No load loss occurred during any 30-s interval.




# BELGIUM




# DENMARK




# FRANCE




# GERMANY




# ITALY




# NETHERLANDS




# NORWAY




# PORTUGAL




# SPAIN




# SWEDEN




# SWITZERLAND




# UNITED KINGDOM




## NOR-DEN




## NOR-DEN-SWE-GER



# NORTHERN EUROPE




# SWI-FRA







## SWI-GER




## NORTHWEST EUROPE




## SWI-ITA



## SPA-POR-GIB



# WESTERN EUROPE



## Supporting References

- S1. Jacobson, M.Z., Delucchi, M.A., Cameron, M.A., Coughlin, S.J., Hay, C., Manogaran, I.P., Shu, Y., and von Krauland, A.-K. (2019). Impacts of Green New Deal energy plans on grid stability, costs, jobs, health, and climate in 143 countries, *One Earth*, 1, 449-463.
- S2. IEA (International Energy Agency). World Energy Statistics 2018. OECD Publishing, Paris.
- S3. EIA (Energy Information Administration). U.S. International Energy Outlook 2016. DOE/EIA-0484. Available online: [http://www.eia.gov/forecasts/ieo/pdf/0484\(2016\).pdf](http://www.eia.gov/forecasts/ieo/pdf/0484(2016).pdf).
- S4. Jacobson, M.Z., and Jadhav, V. (2018). World estimates of PV optimal tilt angles and ratios of sunlight incident upon tilted and tracked PV panels relative to horizontal panels. *Solar Energy* 169, 55-66.
- S5. Enevoldsen, P., and M.Z. Jacobson (2021). Data investigation of installed and output power densities of onshore and offshore wind turbines worldwide, *Energy for Sustainable Development*, 60, 40-51.